

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Saline	Fraction SE 1/4 SW 1/4 SW 1/4	Section number 3	Township number T 14 S R 2 W E/W	Range number			
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Don Mattison R.R. or street: Rt. 1 City, state, zip code: New Cambria Kans. 67470					
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6" in. Completion date _____ Well depth 56 ft. 3-28-78				
		<p style="text-align: center;">In feet below surface</p>		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
5. Type and color of material			From	To	9. Casing: Material _____ Height: <u>Above</u> or below Threaded _____ Welded _____ Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 4 in. to 56 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. #200			
Alluvium: Clay & silt, sandy Sand, fine to medium Gravel, fine to coarse & sand Silt, sandy, gray Gravel, fine to coarse, silty Clay, silty, gray-brown Gravel, fine to coarse & sand					10. Screen: Manufacturer's name Shop Type slots Dia. 4" Slot/gauze 3/32 Length 3' Set between 53 ft. and 56 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8"			
					11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 3-28-78			
					12. Pumping level below land surfaces: 29 ft. after 1/2 hrs. pumping 25 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.			
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.			
					16. Nearest source of possible contamination: ft. 100 Direction W Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
(Use a second sheet if needed)					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydraulic Drilling Co 126 Business name License No. Address Salina Kans Signed Ed Jant Date 3-31-78 Authorized representative		
			19. Remarks:					
			Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

T 14 S R 2 W E/W Sec 3 - SE 1/4 SW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5