

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <i>Saline</i>	Fraction <i>NW 1/4 NW 1/4 NE 1/4</i>	Section number <i>5</i>	Township number <i>T 14 S</i>	Range number <i>R 2 W E/W</i>	
2. Distance and direction from nearest town or city: Street address of well location if in city: <i>1 NE Salina</i>			3. Owner of well: <i>Webb Plumer</i> R.R. or street: <i>Rt 3</i> City, state, zip code: <i>Salina Kans 67401</i>				
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. <i>6</i> in. Completion date <i>9-29-76</i> Well depth <i>30</i> ft.			
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
<i>Alluvium:</i>				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <i>None</i> <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
<i>Clay &amp; silt, gray &amp; buff</i>		<i>0</i>	<i>23</i>	9. Casing: Material <input type="checkbox"/> Height: <i>above</i> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <i>12</i> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <i>4</i> in. to <i>30</i> ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <i>Saline 40</i>			
<i>Gravel medium to fine &amp; sand</i>		<i>23</i>	<i>27.5</i>	10. Screen: Manufacturer's name <i>Serp</i> Type <i>Serp</i> Dia. <i>4"</i> Slat/gauze <i>3/32</i> Length <i>6'</i> Set between <i>24</i> ft. and <i>30</i> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <i>3/8"</i>			
<i>Wilmington fm:</i>				11. Static water level: <input type="checkbox"/> mo./day/yr. <i>22.5</i> ft. below land surface Date <i>9-29-76</i>			
<i>Shale, gray &amp; gypsum</i>		<i>27.5</i>	<i>30</i>	12. Pumping level below land surfaces: <i>27</i> ft. after <i>1</i> hrs. pumping <i>6</i> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <i>6</i> g.p.m.			
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>			
				14. Well head completion: <input type="checkbox"/> Pitless adapter <i>12</i> inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <i>3</i> ft. to <i>13</i> ft.			
				16. Nearest source of possible contamination: ft. <i>200'</i> Direction <i>E</i> Type <i>Oil wells</i> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation:  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: <i>Temporary well - water too salty for use Cl - 1470 ppm Total H - about 3400 ppm</i>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Hydraulic Drilling</i> <i>126</i> Business name <i>Salina Kans</i> License No. Address <i>Salina Kans</i> Signed <i>Ed Furr</i> <i>10-4-76</i> Date Authorized representative			

T 14 R 2 W E S NW/NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5