


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction nw 1/4 nw 1/4 SW/4	Section number 8	Township number T 14 S	Range number R 2W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 2e Salina, Ks.			3. Owner of well: Salina Country Club R.R. or street: Box 777 City, state, zip code: Salina, Ks.			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		6. Bore hole dia. 30 in. Completion date _____ Well depth 51 ft. 9-23-77	
5. Type and color of material			From		To	
			Top Soil		0	2
			Clay		2	17
			Fine Sand		17	30
			Sand Gravel		30	49
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
			9. Casing: Material _____ Height: Above _____ Threaded _____ Welded _____ Surface 24 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 51 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. sch 40		10. Screen: Manufacturer's name _____ Peerless Type pvc Dia. 16 Slot/gauze 1/8" Length 20' Set between 31 ft. and 51 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"	
			11. Static water level: _____ mo./day/yr. 20 ft. below land surface Date 9-23-77		12. Pumping level below land surfaces: 40 ft. after 4 hrs. pumping 400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 400 g.p.m.	
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		14. Well head completion: <input type="checkbox"/> Pitless adapter 24 Inches above grade	
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neap cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 20 ft.		16. Nearest source of possible contamination: ft. 1000 Direction e Type river Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No	
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible _____ Turbine _____ <input type="checkbox"/> Jet _____ Reciprocating _____ <input type="checkbox"/> Centrifugal _____ Other _____		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name License No. Address R2 Great Bend, Ks. Signed Kelly Price Date 9-23-77 Authorized representative	
18. Elevation:			19. Remarks: (Use a second sheet if needed)		20. Water well contractor's certification: (continued)	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

32

10/2/5

T
R
Sec
17
-2
8
C
b
D
1/4
1/4