

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 8	Township number T 14 S R	Range number 2W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1/2 Mi. E Salina			3. Owner of well: Salina City Sewage Dept. R.R. or street: Shit-hook Station City, state, zip code: Salina Kansas 67401			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map:		6. Bore hole dia. 7 in. Completion date June 10, 1979 Well depth 62.5 ft.	
5. Type and color of material			From		To	
			in feet			
Alluvium:					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
4/6 Clay + silt, gray + brown			0		24	
Gravel, fine to coarse + sand			24		70	
Wellington fm:					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Shale, blue-gray			70		71	
					9. Casing: Material _____ Height <u>Above</u> or below Threaded _____ Welded _____ Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 62.5 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200	
					10. Screen: Manufacturer's name Slup Type Slots Dia. 5" Slot/gauze 3/32" Length 5' Set between 57.5 ft. and 62.5 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8"	
					11. Static water level: _____ mo./day/yr. 19.5 ft. below land surface Date 5/8/79	
					12. Pumping level below land surfaces: ND ft. after 0.6 hrs. pumping 60 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 150 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 3 ft. to 13 ft.	
					16. Nearest source of possible contamination: ft. 200' Direction W Type Sludge hole Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: _____ Not installed Manufacturer's name Myers Model number SKG HP 2 Volts 220 Length of drop pipe 35 ft. capacity 35 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other	
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydromatic Drilling 126 Business name License No. Address Salina, Kansas Signed Del Fero Date 6/14/79 Authorized representative	
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

1213

T 14 R 20 W 8 NWSE NW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5