

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 16	Township number T 14 S R	Range number 2 W E/W	
2. Distance and direction from nearest town or city: Street address of well location if in city: 2.5 Mi E Salina			3. Owner of well: Metcon Const. Co R.R. or street: 2141 Centennial Rd City, state, zip code: Salina Ks 67401				
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 6 in. Completion date _____ Well depth 38 ft. 7/9/79			
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Alluvium:				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Clay + silt, gray - brown		0	24	9. Casing: Material _____ Height: <u>Above</u> or below Threaded _____ Welded _____ Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 4 in. to 38 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200			
Gravel, medium to coarse + sand, fine		24	38	10. Screen: Manufacturer's name Shup Type slots Dia. 4" Slot/gauze 1/16" Length 3' Set between 35 ft. and 38 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/10"			
Wellington:				11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 7/9/79			
Shale, gray-green + dolomite		38	41	12. Pumping level below land surfaces: ND ft. after 1/2 hrs. pumping 15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.			
				16. Nearest source of possible contamination: ft. 120 Direction E Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydraulic Drilling 126 Business name _____ License No. _____ Address Salina, Ks Signed O. J. Fent Date 8/20/79 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

14

01212

T
R
E
S
E
C
1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5