

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <u>Saline</u>	Fraction <u>SE 1/4 SW 1/4 SW 1/4</u>	Section number <u>29</u>	Township number <u>T 14</u>	Range number <u>S R 2W</u>	E/W
2. Distance and direction from nearest town or city: <u>2 miles E. Salina</u>				3. Owner of well: <u>Harry Cline</u>			
Street address of well location if in city:				R.R. or street: <u>Rt. 3</u>			
				City, state, zip code: <u>Salina Ks. 67401</u>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>6</u> in. Completion date <u>5-6-77</u>			
N				Well depth <u>46</u> ft.			
W		E		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug			
S				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
1 Mile		1 Mile		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry			
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock			
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material <u>Plastic</u> Height: <u>Above</u> or below			
				Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in.			
				RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>15</u> lbs./ft.			
				Dia. <u>4</u> in. to <u>46</u> ft. depth Wall Thickness: inches or			
				Dia. <u>4</u> in. to <u>46</u> ft. depth gage No. <u>54 40</u>			
5. Type and color of material		From		To		10. Screen: Manufacturer's name <u>Slap</u>	
<u>Alluvium:</u>						Type <u>slots</u> Dia. <u>4"</u>	
<u>Clay, silty gray + tan</u>		<u>0</u>		<u>19</u>		Slot/gauze <u>3/32"</u> Length <u>3'</u>	
<u>Sand, fine, silty</u>		<u>19</u>		<u>31</u>		Set between <u>43</u> ft. and <u>46</u> ft.	
<u>Gravel, fine + sand</u>		<u>31</u>		<u>34</u>		<u>43</u> ft. and <u>46</u> ft.	
<u>Clay, silty brown</u>		<u>34</u>		<u>36</u>		Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>3/8</u>	
<u>Gravel, fine to coarse + sand, silty</u>		<u>36</u>		<u>45</u>		11. Static water level: <u>22</u> ft. below land surface Date <u>5-6-77</u>	
<u>Wellington fm:</u>						12. Pumping level below land surfaces:	
<u>Shale, gray + red</u>		<u>45</u>		<u>50</u>		<u>34</u> ft. after <u>12</u> hrs. pumping <u>10</u> g.p.m.	
						<u>      </u> ft. after <u>      </u> hrs. pumping <u>      </u> g.p.m.	
						Estimated maximum yield <u>15</u> g.p.m.	
						13. Water sample submitted: <u>      </u> mo./day/yr.	
						<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>      </u>	
						14. Well head completion:	
						<input type="checkbox"/> Pitless adapter <u>12</u> inches above grade	
						15. Well grouted? <input checked="" type="checkbox"/> Y	
						With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
						Depth: From <u>0</u> ft. to <u>10</u> ft.	
						16. Nearest source of possible contamination:	
						ft. <u>1000</u> Direction <u>E</u> Type <u>Oil field</u>	
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> X Not installed	
						Manufacturer's name <u>      </u>	
						Model number <u>      </u> HP <u>      </u> Volts <u>      </u>	
						Length of drop pipe <u>      </u> ft. capacity <u>      </u> g.p.m.	
						Type:	
						<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
						<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
						<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:			
Topography:		<u>Chloride 780 ppm</u>		This well was drilled under my jurisdiction and this report			
<input type="checkbox"/> Hill				is true to the best of my knowledge and belief.			
<input type="checkbox"/> Slope				<u>Hydraulic Drilling</u> <u>126</u>			
<input type="checkbox"/> Upland				Business name <u>Salina Ks</u> License No. <u>      </u>			
<input checked="" type="checkbox"/> Valley				Address <u>      </u>			
				Signed <u>Cl. Fent</u> <u>5-27-77</u> Date <u>      </u>			
				Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5