

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Saline	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 30	Township number T 14 S R 2	Range number 2
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: A. J. Holmquist R.R. or street: R.R. # 3 Box 1 City, state, zip code: Salina, Kansas 6740.		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: <i>BDB</i>		6. Bore hole dia. 9 in. Completion date _____ Well depth 48 ft. 5/12/77	
5. Type and color of material		From		To	
		Top soil		0 7	
		Brown soil		7 15	
		Fine sand		15 30	
		Small gravel		30 48	
		Large gravel		48 --	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Plst Height: Above or below _____ Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 6 in. to 48 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0.280	
				10. Screen: Manufacturer's name _____ Western Plastics Type PVC Dia. 6" Slot/gauze 3/32 Length 10' Set between 38 ft. and 48 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/16 to 3/16	
				11. Static water level: _____ mo./day/yr. 16' ft. below land surface Date 5/12/77	
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 150 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 18" inches above grade	
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 300 Direction North Type Gas tank Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				(Use a second sheet if needed)	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rader Drilling Co. 194 Business name _____ License No. _____ Address Carlton, Kansas 67429 Signed Bruce E. Rader Date 5-22-77 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 14 S R 2 E Sec 30 NW 1/4 1/4 NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5