

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

CEDAR BLUFF DAM

BIDU

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County TREGO	Fraction SW 1/4 SE 1/4 NW 1/4	Section number 26	Township number T 14 S R 22	Range number 22
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: KANSAS STATE PARK AND RESOURCES R.R. or street: (CEDAR BLUFF LAKE), STATE OFFICE BUILDING TOPEKA, KANSAS 66612 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 12-6-78 Well depth 110 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
#2 Top Soil		0	1	9. Casing: Material _____ Height: <u>Above</u> or below Threaded _____ Welded _____ Surface 24 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2788 lbs./ft. Dia. 5 in. to 90 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 12651W		
Buff Clay		1	24	10. Screen: Manufacturer's name PEARLESS PLASTICS Type PVC Dia. 5" Slot/gauze 1/32 Length 20ft Set between 90 ft. and 110 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/4 in		
FINE SAND AND CLAY		24	31	11. Static water level: _____ mo./day/yr. 50 ft. below land surface Date 12-6-78		
MEDIUM SANDS		31	47	12. Pumping level below land surfaces: 51 ft. after 4 hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50-100 g.p.m.		
MEDIUM COURSE SAND		47	57	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
BROWN CLAY		57	65	14. Well head completion: <input type="checkbox"/> Pitless adapter 24 inches above grade		
Buff Clay		65	78	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
Brown Clay with Loose Limestone Layers		78	95	16. Nearest source of possible contamination: ft. 1500 Direction N Type SEWAGE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
MEDIUM COURSE SAND with Small Clay Layers		95	102	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
MEDIUM COURSE SAND		102	108	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON IRRIGATION L38A Business name License No. _____ Address Box 150 Lindbergh, KS Signed Mike Peterson Date 12-14-78 Authorized representative		
DARK BLUE SHALE		108	110			
BROOK 108 ym						
108 50 55						
2162 103						
58' soil thick						
205 4'						
Not Og		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		2162 (TOPG)				

T 14 S R 22 SE SE NW 1/4 1/4 1/4