

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Just Downer

1. Location of well: County TREGO Xraction SW 1/4 NE 1/4 SW 1/4 Section number 14 Township number T 14 S R 24 Range number 24 EW	
2. Distance and direction from nearest town or city: 13 miles South 3. Owner of well: Keith Dienes Street address of well location if in city: 3 1/2 West of Wakeeney, Mo. R.R. or street: R.R. City, state, zip code: Ransom, KS, 67572	
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>1 Mile</p> </div> <div> </div> </div>	
5. Type and color of material	
	From To
CLAY	0 19
SAND	19 26
SHALE	26 29
BROCK 26	
2253	
26	
2227	
26	
12	
14' Not in Cg.	
6. Bore hole dia. 9 in. Completion date 5/14/79 Well depth 29 ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material P/ST Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia 5 in. to 29 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250	
10. Screen: Manufacturer's name Jess & Howell Type plastic Dia. 5" Slot/gauze 1/16 Length 10' Set between 29 ft. and 19 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4-5/8"	
11. Static water level: _____ mo./day/yr. 12 ft. below land surface Date 5/14/79	
12. Pumping level below land surfaces: NOT DONE _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
14. Well head completion: NOT DONE <input type="checkbox"/> Pitless adapter _____ Inches above grade	
15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.	
16. Nearest source of possible contamination: ft. 200 Direction NORTH Type CORRAIS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: CONCRETE SLAB TO BE INSTALLED BY CUSTOMER AT GROUND SURFACE. 2253
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. HILL CITY, KS. Business name D & L Drilling License No. 303 Address _____ Signed Allen J. Jones Date 6-4-79 Authorized representative	

T 14 S R 24 EW 14 SWESW