

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <b>SALINE</b>		<b>SE 1/4 NE 1/4 SW 1/4</b>	<b>25</b>	<b>T 14 S</b>	<b>R 3 E/W</b>
Distance and direction from nearest town or city street address of well if located within city? <b>2267 LELAND WAY</b>					
2 WATER WELL OWNER: <b>JOHN REH</b>					
RR#, St. Address, Box # : <b>2267 LELAND WAY</b>			Board of Agriculture, Division of Water Resources		
City, State, ZIP Code : <b>SALINA, KS, 67401</b>			Application Number:		
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <b>57</b> ft. ELEVATION: <b>1240</b>			
<p>1 Mile</p>		Depth(s) Groundwater Encountered 1. <b>16.3</b> ft. 2. . ft. 3. . ft. WELL'S STATIC WATER LEVEL <b>16.3</b> ft. below land surface measured on mo/day/yr <b>6-30-98</b> Pump test data: Well water was <b>21</b> ft. after <b>1</b> hours pumping <b>30</b> gpm Est. Yield <b>7.5</b> gpm: Well water was . ft. after . hours pumping . gpm Bore Hole Diameter <b>9</b> in. to <b>57</b> ft. and . in. to . ft. WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial <u>7 Lawn and garden only</u> 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes. . No. <b>X</b> ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes <b>X</b> No			
		5 TYPE OF BLANK CASING USED:			
		1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued <b>X</b> Clamped . 2 <u>PVC</u> 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded . 7 Fiberglass Threaded.			
		Blank casing diameter <b>5</b> in. to <b>52</b> ft. Dia. . in. to . ft. Dia. . in. to . ft. Casing height above land surface <b>16</b> in. weight <b>160</b> lbs./ft. Wall thickness or gauge No. <b>SDR 26</b>			
		TYPE OF SCREEN OR PERFORATION MATERIAL: <u>7 PVC</u> 10 Asbestos-cement 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) . 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)			
SCREEN OR PERFORATION OPENINGS ARE: 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 1 Continuous slot <u>3 Mill slot .035</u> 6 Wire wrapped 9 Drilled holes 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)					
SCREEN-PERFORATED INTERVALS: From <b>52</b> ft. to <b>57</b> ft. From . ft. to . ft. From . ft. to . ft. From . ft. to . ft. GRAVEL PACK INTERVALS: From <b>45</b> ft. to <b>57</b> ft. From . ft. to . ft. From . ft. to . ft. From . ft. to . ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout <u>3 Bentonite</u> 4 Other					
Grout Intervals: From <b>2</b> ft. to <b>26</b> ft. From . ft. to . ft. From . ft. to . ft.					
What is the nearest source of possible contamination:					
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well <u>3 Watertight sewer lines</u> 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage					
Direction from well? <b>WEST</b>		How many feet? <b>40</b>			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	FILL DIRT			
2	9	CLAY BROWN SOFT			
9	22	SAND FINE SILTY TAN			
22	29	SAND FINE TAN			
29	35	CLAY TAN SILTY			
35	57	SAND FINE TO COARSE TAN			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) <u>constructed</u> , (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <b>6-30-98</b> and this record is true to the best of my knowledge and belief. Kansas					
Water Well Contractor's License No. <b>388</b>		This Water Well Record was completed on (mo/day/yr) <b>6-30-98</b>			
under the business name of <b>PESTINGER PUMP SERVICE</b>		by (signature) <i>Paul Pestinger</i>			