


LOCATION OF WATER WELL		Fraction	Section Number		Township Number		Range Number	
County <u>Saline</u>		<u>SW</u> $\frac{1}{4}$ SW $\frac{1}{4}$ SE $\frac{1}{4}$	<u>10</u>		T <u>14</u> S		R <u>3W</u> E/W	
Distance and direction from nearest town or city? <u>3/4 Mi. W. Salina</u>				Street address of well if located within city?				
2 WATER WELL OWNER: <u>City of Salina</u>				Board of Agriculture, Division of Water Resources				
RR#, St. Address, Box #: <u>300 W. Ash</u>				Application Number:				
City, State, ZIP Code: <u>Salina, Kansas 67401</u>								
3 DEPTH OF COMPLETED WELL: <u>71</u> ft. Bore Hole Diameter: <u>6</u> in. to <u>71</u> ft. and in. to ft.								
Well Water to be used as: <input checked="" type="checkbox"/> 1 Domestic 3 Feedlot 6 Oil field water supply 8 Air conditioning 11 Injection well <input type="checkbox"/> 2 Irrigation 4 Industrial 7 Lawn and garden only 9 Dewatering 12 Other (Specify below) <u>City dog pound utility</u>								
Well's static water level: <u>14</u> ft. below land surface measured on <u>11/8/79</u> Nov. month <u>8</u> day <u>1979</u> year								
Pump Test Data <u>26</u> Well water was <u>26</u> ft. after <u>1</u> hours pumping <u>20</u> gpm								
Est. Yield <u>35</u> gpm: Well water was ft. after hours pumping gpm								
4 TYPE OF BLANK CASING USED: 1 Steel <input checked="" type="checkbox"/> 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: <u>Glued</u> <input checked="" type="checkbox"/> Clamped 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded 3 Fiberglass Threaded								
Blank casing dia: <u>4</u> in. to <u>68</u> in. Dia in. to ft. Dia in. to ft.								
Casing height above land surface: <u>12</u> in., weight lbs./ft. Wall thickness or gauge No. <u>200</u>								
TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless steel 5 Fiberglass <input checked="" type="checkbox"/> 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) 12 None used (open hole)								
Screen or Perforation Openings Are: 1 Continuous slot 3 Mill slot 5 Gauzed wrapped <input checked="" type="checkbox"/> 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes								
7 Torch cut 10 Other (specify)								
Screen-Perforation Dia: <u>1/16</u> in. to <u>71</u> ft. Dia in. to ft. Dia in. to ft.								
Screen-Perforated Intervals: From <u>68</u> ft. to <u>71</u> ft. From ft. to ft.								
Gravel Pack Intervals: From <u>55</u> ft. to <u>71</u> ft. From ft. to ft.								
5 GROUT MATERIAL: <input checked="" type="checkbox"/> 1 Neat cement 2 Cement grout 3 Bentonite 4 Other								
Grouted Intervals: From <u>3</u> ft. to <u>13</u> ft. From ft. to ft. From ft. to ft.								
What is the nearest source of possible contamination: 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well <input checked="" type="checkbox"/> 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below) 13 Watertight sewer lines								
Direction from well: <u>west</u> How many feet <u>55</u> ? Water Well Disinfected? <u>Yes</u> <input checked="" type="checkbox"/> No								
Was a chemical/bacteriological sample submitted to Department? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, date sample was submitted month day year: Pump Installed? Yes <input checked="" type="checkbox"/> No								
If Yes: Pump Manufacturer's name: <u>Myers</u> Model No. <u>S2G-72-7A</u> HP <u>3/4</u> Volts <u>230</u>								
Depth of Pump Intake <u>52</u> ft. Pumps Capacity rated at <u>15</u> gal./min.								
Type of pump: <input checked="" type="checkbox"/> 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other								
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1)</u> constructed, <u>(2)</u> reconstructed, or <u>(3)</u> plugged under my jurisdiction and was completed on <u>Nov.</u> month <u>23</u> day <u>1979</u> year								
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>126</u>								
This Water Well Record was completed on <u>Dec</u> month <u>5</u> day <u>1979</u> year under the business name of <u>Hydraulic Drilling Co</u> by (signature) <u>[Signature]</u>								
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG	
		0	30	clay, brown				
		30	41	sand and gravel, medium				
		41	54	Silt, sandy, tan				
		54	64	sand, fine				
		64	71	sand and gravel, coarse				
		71	75	sand & gravel, medium				
		75	81	silt, gray				
		81	85	sand & gravel, silty				
		85	89	shale, gray				
ELEVATION <u>1232</u>								
Depth(s) Groundwater Encountered 1. <u>30</u> ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)								
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.								