


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>Saline</u>	Township name	Fraction <u>SESE NW</u>	Section number <u>10</u>	Town number <u>145</u>	Range number <u>3W</u>
Distance and direction from nearest town or city: <u>1/2 mi W. Salina</u>			3 Owner of well: <u>Karl Keenher</u>			
Street address of well location if in city:			Address: <u>RT. 1 Salina KS</u>			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map: <u>Feet below L.S.</u>			4 Well depth: <u>66</u> ft. Date of completion <u>8-29-75</u> Well diameter <u>5</u> in.
2 Type and color of material			From		To	
			<u>alluvium</u>			
			<u>Clay, buff & gray</u>		<u>0</u>	<u>29</u>
			<u>gravel fine & sand</u>		<u>29</u>	<u>45</u>
			<u>gravel fine to coarse & sand</u>		<u>45</u>	<u>70</u>
					5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
					7 Casing: Material <u>RMP</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>5</u> in. to <u>66</u> ft. depth Weight <u> </u> lbs./ft. <u> </u> Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					8 Screen: Manufacturer <u>Slup</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>6'</u> Set between <u>60</u> ft. and <u>66</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>2.5 mm</u>	
					9 Static water level: <u>15.5</u> ft. below land surface Date <u>8-28-75</u>	
					10 Pumping level below land surfaces: <u>38</u> ft. after <u>12</u> hrs. pumping <u>30</u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>50</u> g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>3</u> ft. to <u>13</u> ft.	
					14 Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Hydramatic Drilling</u> <u>126</u> Business name License No. Address <u>Salina KS</u> Signed <u> </u> Date <u>8-10-75</u> Authorized representative			