

1 LOCATION OF WATER WELL:		Fraction		Section Number		Township Number		Range Number	
County: Saline		NW 1/4 NW 1/4 NW 1/4		24		T 14 S		R 3 EW	
Distance and direction from nearest town or city street address of well if located within city? 701 S. Ninth, Salina									
2 WATER WELL OWNER: Bob Ott RR#, St. Address, Box #: 1315 Beverly City, State, ZIP Code: Salina, KS 67401 Board of Agriculture, Division of Water Resources Application Number:									
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:			4 DEPTH OF COMPLETED WELL: 58 ft. ELEVATION:						
			Depth(s) Groundwater Encountered 1. 40 ft. 2. ft. 3. ft.						
			WELL'S STATIC WATER LEVEL 38.00 ft. below TOC measured on mo/day/yr 06-08-93						
			Pump test data: Well water was ft. after hours pumping gpm						
			Est. Yield gpm: Well water was ft. after hours pumping gpm						
			Bore Hole Diameter 7. 7/8. in. to 53 ft. and in. to ft.						
WELL WATER TO BE USED AS:			5 Public water supply 8 Air conditioning 11 Injection well						
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)									
2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well									
Was a chemical/bacteriological sample submitted to Department? Yes.....No.....; If yes, mo/day/yr sample was submitted									
Water Well Disinfected? Yes No									
5 TYPE OF BLANK CASING USED:									
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued.....Clamped.....									
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded.....									
7 Fiberglass Threaded.....									
Blank casing diameter 2 in. to 35 ft. Dia in. to ft. Dia in. to ft.									
Casing height above land surface 0 in. weight lbs./ft. Wall thickness or gauge No. Sch. 40									
TYPE OF SCREEN OR PERFORATION MATERIAL:									
1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement									
2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify)									
12 None used (open hole)									
SCREEN OR PERFORATION OPENINGS ARE:									
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)									
2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes									
7 Torch cut 10 Other (specify)									
SCREEN-PERFORATED INTERVALS: From 35 ft. to 50 ft. From ft. to ft.									
From ft. to ft. From ft. to ft.									
GRAVEL PACK INTERVALS: From 33 ft. to 53 ft. From ft. to ft.									
From ft. to ft. From ft. to ft.									
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other									
Grout Intervals: From 0 ft. to 30 ft. From 30 ft. to 33 ft. From ft. to ft.									
What is the nearest source of possible contamination:									
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well									
2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well									
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)									
13 Insecticide storage									
Direction from well? South How many feet? 40									
FROM TO LITHOLOGIC LOG FROM TO PLUGGING INTERVALS									
0 7 BRN-RED/BRN Silty Clay									
7 23 Clay, GY/BRN-BRN, Silty									
23 38 VF-M SND									
38 45 F-C SND									
45 53 F-C SND/F-M GRVL									
MT									
Flushmount									
#00082101									
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/yr) 05-20-93 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 527 This Water Well Record was completed on (mo/day/yr) by (signature) Gary Ray under the business name of Geolore Services, Inc.									
INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send two copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.									