

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: Saline		NW ¼ NW ¼ NW ¼	24	T 14 S	R 3 E W
Distance and direction from nearest town or city street address of well if located within city: 701 S. Ninth, Salina					
2 WATER WELL OWNER: Bob Ott RR#, St. Address, Box #: 1315 Beverly Board of Agriculture, Division of Water Resources City, State, ZIP Code: Salina, KS 67401 Application Number:					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL... 50 ft. ELEVATION:			
<p>1 Mile</p>		Depth(s) Groundwater Encountered 1... 40 ft. 2... ft. 3... ft. WELL'S STATIC WATER LEVEL . 38.79 ft. below TOC measured on mo/day/yr Pump test data: Well water was ... ft. after ... hours pumping ... gpm Est. Yield ... gpm: Well water was ... ft. after ... hours pumping ... gpm Bore Hole Diameter . 7 7/8 in. to 50 ft., and ... in. to ... ft. WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes No; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes No			
5 TYPE OF BLANK CASING USED: 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded Blank casing diameter . 2 in. to 35 ft., Dia . in. to . ft., Dia . in. to . ft. Casing height above land surface . 0 in., weight lbs./ft. Wall thickness or gauge No. SCH. 40 TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 10 Other (specify) SCREEN-PERFORATED INTERVALS: From . 35 ft. to 50 ft., From . ft. to . ft. GRAVEL PACK INTERVALS: From . 33 ft. to 50 ft., From . ft. to . ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grout Intervals: From . 0 ft. to 30 ft., From . 30 ft. to 33 ft., From . ft. to . ft. What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) Direction from well? NNW How many feet? 50					
FROM TO		LITHOLOGIC LOG		FROM TO PLUGGING INTERVALS	
0	25.5	BRN SLTY CLY			
25.5	44	VF-C SND			MW3
44	50	F-C SND/F-M GRVL			Flushmount
					#00082224
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was 1 constructed, 2 reconstructed, or 3 plugged under my jurisdiction and was completed on (mo/day/year) 05-21-93 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 5027 This Water Well Record was completed on (mo/day/yr) by (signature) Doug Ray under the business name of GeoCore Services, Inc.					
INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.					