


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 25	Township number T 14	Range number S R 3W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: Ohio + Buckeye, Saline				3. Owner of well: Kraus Pump + Supply R.R. or street: Rt. 1 City, state, zip code: Salina, Kans		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 7 in. Completion date _____ Well depth 485 ft. 6/15/79		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Alluvium:						9. Casing: Material _____ Height: above or below Threaded _____ Welded _____ Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 48.5 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200
Clay + silt, gray, brown + light gray-green		0		30		10. Screen: Manufacturer's name Shop
Gravel, fine + sand		30		35		Type slots Dia. 5" Slot/gauze 3/32 Length 5' Set between 43.5 ft. and 48.5 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8"
Silt, gray + sand, fine to coarse		35		40		11. Static water level: _____ mo./day/yr. 17.5 ft. below land surface Date 6/15/79
Gravel, medium to fine + sand		40		47		12. Pumping level below land surfaces: ND ft. after 1/2 hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 60 g.p.m.
Wellington fm:						13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Shale, yellow, firm		47		48.5		14. Well head completion: Pitless adapter 12 inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 3 ft. to 13 ft.
						16. Nearest source of possible contamination: ft. _____ Direction _____ Type ND Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No
						17. Pump: <input checked="" type="checkbox"/> Nat installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydraulic Pulley 0126 Business name _____ License No. _____ Address Salina, Kans Signed Orl Faust 6/30/79 Authorized representative Date
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5