WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section	number	Township number Range number
1. Location of well:	Saline	5E 1/4 NW1/4 SE	1/4	30	0	T 14 S R 3 W E/W
2. Distance and direction from nearest town or city: 3. Owner of well: Ray Fishbuth						
Street address of well location if in city: 736 Scott				street:	73	6 Scitt
				tate, zip	code:	Salina Kans 67401
4. Locate with "X"		Sketch map:				6. Bore hole dia in. Completion date Well depth 58 ft. Out: 19,1976
1						7 Cable tool _X Rotary Driven Dug
	 NE					Hollow rod Jetted Bored Reverse rotary
<u> </u>	!	75°)				8. Use: Domestic Public supply Industry
w	E .					Irrigation Air conditioning Stock
sw	X i SE					9. Casing: Material Height: Above or below
						Threaded Welded iSurface in.
s					RMP PVC XWeightIbs./ft.	
1 Mile1				T -		Dia. 4 in. to 58 ft. depth Wall Thickness; inches or Dia. in. to ft. depth gage No 5 head 40
5. Type and color of	material			From	То	10. Screen: Manufacturer's name
~/	1 + silt =	2.41.00		0	35	Shop
	ay + silt, gr	agr bar t		 		Type
Sa	nol fine			35	40	Set between 55 ft. and 58 ft.
	vel fine to me	edium + saud		40	54	ft. andft. Gravel pack? Size range of material 3/8 "
	•					11. Static water level:mo./day/yr.
(4)	quel, fine to	Coarse & soud		27	58	_Al_ft. below land surface Date Oct. 19,191
						12. Pumping level below land surfaces:ft. after
						ft. after hrs. pumping g.p.m.
						Estimated maximum yieldg.p.m.
						13. Water sample submitted: mo./day/yr.
					,	Yes No Date
				 		14. Well head completion: Pitless adapter Inches above grade
						15. Well grouted?
						With: X Neat coment Bentonite Concrete Depth: From 3 ft. to ft.
						16. Nearest source of possible contamination:
						ft Direction Type
		 		<u> </u>		Well disinfected upon completion? X YesNo
						17. Pump: Not installed Manufacturer's name
						Model number HP Volts
				ļ		Length of drop pipe ft. capacityg.p.m. Type:
				<u> </u>		Submersible Turbine
		-hank if moded)				Jet Reciprocating Other
10 51		sheet if needed)		<u> </u>	<u> </u>	20. Water well contractor's certification:
18. Elevation:	19. Remarks:					This well was drilled under my jurisdiction and this report
						is true to the best of my knowledge and belief.
Topography:						Busifess name C 2 License No.
Hill Slope						Address Salinas Hanna
Upland						Signed Authorized representative Date
X Valley						Authorized representative

NWSE