


1 LOCATION OF WATER WELL: County: <u>SALINE</u>		Fraction: <u>NE 1/4 NW 1/4 SW 1/4</u>	Section Number: <u>25</u>	Township Number: <u>T 14 S</u>	Range Number: <u>R 3 EW</u>																																										
Distance and direction from nearest town or city street address of well if located within city? <u>200 E. Wayne</u>																																															
2 WATER WELL OWNER: RR#, St. Address, Box # : City, State, ZIP Code			Board of Agriculture, Division of Water Resources Application Number:																																												
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 			4 DEPTH OF COMPLETED WELL: <u>51 1/2</u> ft. ELEVATION: Depth(s) Groundwater Encountered 1. <u>16</u> ft. 2. <u>16</u> ft. 3. <u>16</u> ft. WELL'S STATIC WATER LEVEL <u>16</u> ft. below land surface measured on mo/day/yr <u>7-31-94</u> Pump test data: Well water was <u>23</u> ft. after <u>1</u> hours pumping <u>15</u> gpm Est. Yield <u>30</u> gpm Well water was <u>23</u> ft. after <u>1</u> hours pumping <u>15</u> gpm Bore Hole Diameter <u>8 1/2</u> in. to <u>21</u> ft. and <u>5</u> in. to <u>51 1/2</u> ft. WELL WATER TO BE USED AS: 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial <u>7</u> Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes <u>X</u> No <u>X</u> ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes <u>X</u> No <u>X</u>																																												
5 TYPE OF BLANK CASING USED: 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: <u>Glued</u> <u>X</u> Clamped <u>X</u> <u>2</u> PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded <u>X</u> Blank casing diameter <u>5</u> in. to <u>41 1/2</u> ft. Dia. <u>160</u> lbs./ft. Wall thickness or gauge No. <u>SDR 26</u> Casing height above land surface <u>16</u> in. weight <u>160</u> lbs./ft. Wall thickness or gauge No. <u>SDR 26</u> TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot 3 Mill slot 5 Gauzed wrapped <u>6</u> Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 3 Torch cut 10 Other (specify) SCREEN-PERFORATED INTERVALS: From <u>41 1/2</u> ft. to <u>51 1/2</u> ft. From <u>41 1/2</u> ft. to <u>51 1/2</u> ft. GRAVEL PACK INTERVALS: From <u>21</u> ft. to <u>51 1/2</u> ft. From <u>21</u> ft. to <u>51 1/2</u> ft.																																															
6 GROUT MATERIAL: GROUT INTERVALS: From <u>0</u> ft. to <u>21</u> ft. From <u>21</u> ft. to <u>51 1/2</u> ft. From <u>51 1/2</u> ft. to <u>51 1/2</u> ft. What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well <u>3</u> Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage Direction from well? <u>WEST</u> How many feet? <u>54</u>																																															
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> <th>FROM</th> <th>TO</th> <th>PLUGGING INTERVALS</th> </tr> </thead> <tbody> <tr> <td>0'</td> <td>7'</td> <td>Compacted silt + Dark Brown clay</td> <td></td> <td></td> <td></td> </tr> <tr> <td>7'</td> <td>17'</td> <td>clay + fine sand mixed</td> <td></td> <td></td> <td></td> </tr> <tr> <td>17'</td> <td>22'</td> <td>Fine Sand</td> <td></td> <td></td> <td></td> </tr> <tr> <td>22'</td> <td>30'</td> <td>Light Brown clay + med. SAND mixed</td> <td></td> <td></td> <td></td> </tr> <tr> <td>30'</td> <td>32'</td> <td>medium SAND AND grey clay mixed</td> <td></td> <td></td> <td></td> </tr> <tr> <td>32'</td> <td>51 1/2'</td> <td>medium-coarse SAND AND gravel</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>						FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS	0'	7'	Compacted silt + Dark Brown clay				7'	17'	clay + fine sand mixed				17'	22'	Fine Sand				22'	30'	Light Brown clay + med. SAND mixed				30'	32'	medium SAND AND grey clay mixed				32'	51 1/2'	medium-coarse SAND AND gravel			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS																																										
0'	7'	Compacted silt + Dark Brown clay																																													
7'	17'	clay + fine sand mixed																																													
17'	22'	Fine Sand																																													
22'	30'	Light Brown clay + med. SAND mixed																																													
30'	32'	medium SAND AND grey clay mixed																																													
32'	51 1/2'	medium-coarse SAND AND gravel																																													
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1)</u> constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>8-3-94</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>523</u> This Water Well Record was completed on (mo/day/yr) <u>8-3-94</u> under the business name of <u>M & D Well Service</u> by (signature) <u>Matthew Janke</u>																																															