

23,622 DI

Check: ☒ White Copy, ☐ Blue Copy, ☐ Pink Copy

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 620-276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME PREMIUM SOURCE AG
COUNTY FINNEY
DATE 9-14-10

LOCATION: NE 1/4 25-24-34 - 2-1/2 MILES SOUTH ON HOLCOMB LANE,
1/2 MILE WEST, 1/4 MILE NORTH
- 1/8TH MILE EAST OF EXISTING WELL

STATIC WATER LEVEL - 245 FT.

TEST # 1

0' TO 1' - TOP SOIL
1' TO 9' - FINE SAND - LOOSE
9' TO 23' - FINE TO MEDIUM SAND & GRAVEL
23' TO 42' - BROWN CLAY
42' TO 55' - FINE TO MEDIUM SAND & GRAVEL
55' TO 83' - FINE TO MEDIUM SAND & GRAVEL - SOME COARSE
83' TO 128' - BROWN CLAY
128' TO 196' - FINE TO MEDIUM SAND & GRAVEL - 10% CLAY
196' TO 210' - BROWN CLAY
210' TO 223' - FINE TO MEDIUM SAND & GRAVEL
223' TO 260' - BROWN SANDY CLAY
260' TO 273' - FINE TO MEDIUM SAND & GRAVEL
273' TO 290' - BROWN CLAY WITH GRAVEL STREAKS
290' TO 312' - FINE TO MEDIUM SAND & GRAVEL
312' TO 342' - BROWN SANDY CLAY
342' TO 376' - FINE TO MEDIUM SAND & GRAVEL
376' TO 393' - BROWN CLAY
393' TO 444' - FINE TO MEDIUM SAND & GRAVEL - LOOSE
444' TO 462' - BROWN YELLOW CLAY - HARD
462' TO 467' - YELLOW CLAY - HARD PULL DOWN
467' TO 485' - SHALE - HARD PULL DOWN