


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

DCC

1. Location of well:	County WALLACE	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 14	Township number T 14	Range number S 40 W
2. Distance and direction from nearest town or city: Street address of well location if in city: SHARON SPRINGS 4 S 3/4 E			3. Owner of well: CITY OF SHARON SPRINGS R.R. or street: City, state, zip code: SHARON SPRINGS KS 67758		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 28 in. Completion date 7-20-78 Well depth 181 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42 lbs./ft. Dia. 16 in. to 137 ft. depth Wall Thickness: inches or Dia. 16 in. to 181 ft. depth gage No. 250		
5. Type and color of material			From	To	10. Screens: Manufacturer's name DUCER Type LOUVER Dia. 16" Slot/gauze 1/16 250 Length 40 Set between 137 ft. and 177 ft. ft. and 177 ft. Gravel pack? YES Size range of material 18
TOP SOIL			0	4	11. Static water level: 106 ft. below land surface Date 12-14-77 mo./day/yr.
CLAY, SAND			4	70	12. Pumping level below land surfaces: 162 ft. after 10 hrs. pumping 680 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 750 g.p.m.
SANDY CLAY, SANDSTONE			70	95	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
M GRAVEL			95	108	14. Well head completion: <input type="checkbox"/> Pitless adapter 36" inches above grade
FINE SAND, SANDY CLAY			108	116	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.
M GRAVEL			116	131	16. Nearest source of possible contamination PASTURE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
CLAY			131	141	17. Pump: _____ Not installed Manufacturer's name LOUVE & BOWLER Model number 6 HP 100 Volts 440 Length of drop pipe 175 ft. capacity 650 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
M GRAVEL			141	160	
CLAY			160	164	
M GRAVEL			164	169	
M GRAVEL, SANDY CLAY			169	177	
Ochre			177	181	
BROCK 177'					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D. H. Dyer Co. Inc. 166 Business name License No. Address Overland Kansas Signed Bill Clifford Date 7-21-78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 14
R 40
Sec 14
1/4 1/4 1/4