

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

DCD

1. Location of well: County Wallace Fraction Middle of South side Section number 22 Township number T 14 S Range number R 40 E/W

2. Distance and direction from nearest town or city: five miles South of Sharon Springs, Kansas
Street address of well location if in city: _____
3. Owner of well: R. D. Walker
R.R. or street: RR #1
City, state, zip code: Sharon Springs, Kansas 67758

4. Locate with "X" in section below: Sketch map:
N
W E
SW SE
S
1 Mile
Middle of South side of SE 1/4, Sec 22, Twp 14, Rge 40

6. Bore hole dia. 30 in. Completion date 1-27-77
Well depth: 237 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material Steel Height: Above or below
Threaded Welded Surface 12 in.
RMP PVC Weight 36 lbs./ft.

Dia. 16 in. to 237 ft. depth; Wall Thickness: inches or
Dia. 2 1/2 in. to 237 ft. depth; gage No. .219

5. Type and color of material	From	To
clay and sand	0	124
medium to good	124	132
clay and rock	132	142
medium to good	142	155
hard rock	155	166
fine medium to good	166	198
sticky clay	198	204
fine medium to good	204	216
sandy clay and clay	216	223
medium to good	223	227
soapstone	227	235
blue	233	237
BROCK 229'		

10. Screen: Manufacturer's name Lakewood Pipe

Type steel Dia. 16"
Sloy gauze 2" Length 90'
Set between 137 ft. and 227 ft.
ft. and _____ ft.
Gravel pack? yes Size range of material 3/8

11. Static water level: 142 ft. below land surface Date 3-18-77

12. Pumping level below land surfaces:
230 ft. after 8 hrs. pumping 720 g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 720 g.p.m.

13. Water sample submitted: no mo./day/yr.
Yes _____ No _____ Date _____

14. Well head completion:
 Pitless adapter 12 inches above grade

15. Well grouted? _____
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: none
ft. _____ Direction _____ Type _____
Well disinfected upon completion? Yes No

17. Pump: _____ Not installed
Manufacturer's name Peerless
Model number _____ HP 100 Volts _____
Length of drop pipe 225 ft. capacity 700 g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation: _____
19. Remarks: _____
Topography:
 Hill
 Slope
 Upland
 Valley

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Northwest Drilling Co. Inc 248
Business name _____ License No. _____
Address Goodland, Kansas
Signed Don Haney Date 5-24-77
Authorized representative

14 40 22 1/4 SE