


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

SOUTH FLATS

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

B3B3

1. Location of well:	County Wallace	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 24	Township number T 14 S R 40 E/W	Range number
2. Distance and direction from nearest town or city: 7 miles South East of Sharon Springs, Kansas Street address of well location if in city:			3. Owner of well: Orville Walker R.R. or street: Sharon Springs, Kansas City, state, zip code:		
4. Locate with "X" in section below: Sketch map: NW 1/4 NW 1/4 NW 1/4 Sect 24 Twp 14 Rge 40  1 Mile			6. Bore hole dia 30 in. Completion date Well depth 235 ft. 9-6-75		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP: <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 235 ft. depth, Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth, gage No. .219		
			10. Screens: Manufacturer's name W. A. Brown Enterprises Type steel Dia. 16 Slot/gauze 3 in. Length 100 Set between 135 ft. and 235 ft. Gravel pack? <input checked="" type="checkbox"/> yes <input type="checkbox"/> no Size range of material 3/4 in.		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 142 ft. below land surface Date 10-14-75		
			12. Pumping level below land surfaces: 178 ft. after 2 hrs. pumping 600 g.p.m. 189 ft. after 3 hrs. pumping 800 g.p.m. Estimated maximum yield _____ g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ mo./day/yr.		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> _____ 12 inches above grade		
			15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
			16. Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould Model number Turbine HP 100 Volts _____ Length of drop pipe 200 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Northwest Drilling Co., Inc. Business name License No. _____ Address Scott City, Kansas Signed Bentley Date 12-2-75 Authorized representative		
19. Remarks: 3641 (TOPO)					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 14 S R 40 E NW 1/4 NW 1/4 NW 1/4