


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

BCC

1. Location of well: Well # 1X	County Wallace	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 28	Township number T 14 S	Range number R 40 X/W
2. Distance and direction from nearest town or city: 6 Mi. South & 2 west of Sharon Springs Kansas			3. Owner of well: Maxine Branwell R. or street: 3111 S. Monaco Circle City, state, zip code: Denver, Colo. 80222		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. <u>28</u> in. Completion date _____ Well depth <u>240</u> ft. <u>6-19-77</u>
Overburden			0	105	7. <u>700</u> Cable tool Rotary _____ Driven _____ Dug _____ _____ Hollow rod _____ Jetted _____ Bored _____ <input checked="" type="checkbox"/> Reverse rotary
Clay & cemented sand			105	128	8. Use: _____ Domestic _____ Public supply _____ Industry <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other
Sand			128	155	9. Casing: Material <u>steel</u> Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP _____ PVC _____ Weight <u>40</u> lbs./ft. Dia. <u>16</u> in. to <u>190</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>230</u> ft. depth gage No. <u>219</u>
Clay & cemented sand M hard			155	163	10. Screen: Manufacturer's name W. A. Brown Type Free Flo Dia. <u>16</u> Slot/gage _____ Length <u>10</u> Set between <u>230</u> ft. and <u>240</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>5/8"</u>
Sand with 3' clay			163	176	11. Static water level: _____ mo./day/yr. <u>140</u> ft. below land surface Date <u>6-15-77</u>
Clay			176	181	12. Pumping level below land surfaces: <u>170</u> ft. after <u>5</u> hrs. pumping <u>1500</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>2000</u> g.p.m.
Sand (fine)			181	192	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
Cemented Sand (hard)			192	196	14. Well head completion: _____ Pitless adapter <u>12</u> Inches above grade
Sand (fine) & a little cemented sand			196	204	15. Well grouted? <input checked="" type="checkbox"/> yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Sand			204	210	16. Nearest source of possible contamination: ft. _____ Direction _____ Type <u>None</u> Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No
Clay & little cemented sand			210	213	17. Pump: _____ Not installed Manufacturer's name <u>Layne</u> Model number <u>770317</u> HP <u>150</u> Volts _____ Length of drop pipe <u>240</u> ft. capacity <u>1500</u> g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other
Sand			229	235	
Clay (yellow)			235	240	
BRICK 235' (Use a second sheet if needed)					
18. Elevation:		19. Remarks:			
Topography: <input checked="" type="checkbox"/> Hill _____ Slope _____ Upland _____ Valley					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ark Valley Pump & Supply 123 Business name _____ License No. _____ Address Box 235 Holly Colo. 81047 Signed <u>W. Smith</u> Date <u>7-30-77</u> Authorized representative					

T 14 R 40 S 28 Sec 28 SW 1/4