

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

AB4

Location of well:	County	Fraction	Section number	Township number	Range number
	Wallace	NE 1/4 NW 1/4 NE 1/4	35	T 14 S	R 40 E/W

Distance and direction from nearest town or city: <u>five miles south of Sharon Springs, Kans</u>	3. Owner of well: <u>R. D. Walker</u>
Street address of well location if in city:	R.R. or street: <u>RR #1</u>
	City, state, zip code: <u>Sharon Springs, Kans. 67758</u>

4. Locate with "X" in section below: Sketch map: NE 1/4 NW 1/4 NE 1/4 Sec 35 Twp 14 Rge 40

6. Bore hole dia. 30 in. Completion date 4-18-77  
Well depth 230 ft.

7. Cable tool  Rotary  Driven  Dug   
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  Irrigation  Air conditioning  Stock  Lawn  Oil field water  Other

9. Casing: Material steel Height: Above or below  
Threaded  Welded  Surface 12 in.  
RMP  PVC  Weight 36 lbs./ft.  
Dia. 16 in. to 230 ft. depth Wall Thickness: inches or  
Dia. 1/2 in. to 230 ft. depth gauge No. 219

5. Type and color of material	From	To
clay sand and rock	0	104
medium to coarse	104	115
clay	115	120
sandy clay	120	130
medium to coarse	130	135
very sandy clay	135	143
medium sand	143	148
sandy clay and rock	148	156
good to coarse	156	165
sand rock and clay	165	184
medium sand	184	190
sandy clay and sand rock	190	198
medium to coarse	198	206
clay and rock	206	209
sand and gravel	209	222
soapstone	222	229
blue	229	230

10. Screen: Manufacturer's name Lakewood Pipe  
Type steel Dia. 16"  
Slot gauze 2" Length 90'  
Set between 132 ft. and 222 ft.  
ft. and ft.

11. Static water level: 127 ft. below land surface Date 4-24-77 mo./day/yr.

12. Pumping test below land surfaces:  
156 ft. after 3 hrs. pumping 800 g.p.m.  
205 ft. after 4 hrs. pumping 1800 g.p.m.  
Estimated maximum yield 1800 g.p.m.

13. Water sample submitted: no mo./day/yr.  
Yes No Date

14. Well head completion:  
12 Pitless adapter 12 inches above grade

15. Well grouted?   
With:  Neat cement  Bentonite  Concrete  
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: none  
ft. Direction Type  
Well disinfected upon completion?  Yes  No

17. Pump:  Not installed  
Manufacturer's name Peerless  
Model number 100 HP 100 Volts  
Length of drop pipe 220 ft. capacity 800 g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

(Use a second sheet if needed)

18. Elevation:	19. Remarks: <u>BROCK 222'</u>	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Northwest Drilling Co. Inc. 24</u> Business name License No. Address <u>Goodland, Kansas</u> Signed <u>Ben Hay</u> Date <u>5-24-77</u> Authorized representative
----------------	--------------------------------	--

Topography:  
 Hill  
 Slope  
 Upland  
 Valley

T 14 S 40 R 40 E W NE 1/4 NW 1/4 NE 1/4