

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WESKAN SE

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

ABD

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County WALLACE	Township name Weskan SE	Fraction NW 1/4 NE 1/4	Section number 22	Town number 14	Range number 41
Distance and direction from nearest town or city: SHARON SPRINGS 45 6 W 1/4 S 1/4 E			3 Owner of well: Edwin Selzer			
Street address of well location if in city:			Address: SHARON SPRINGS KANS.			
Locate with "X" in section below: N		Sketch map:		4 Well depth: 222 ft. Date of completion 8-19-75 Well diameter 26 in.		
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
2		Type and color of material		From	To	7 Casing: Material Steel Height: above Low Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 132 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth
		M GRAVEL SANDY CLAY, SANDSTONE		96	126	8 Screen: Manufacturer W.A. BROWN Type LUPER Dia. 16 Slot/gauze 18-7 Length 90 Set between 132 ft. and 222 ft. Fittings: 1/4 x 9/8 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material —
		M GRAVEL SANDSTONE		126	156	9 Static water level: 105 ft. below land surface Date 8-19-75
		FINE SAND, SANDY CLAY		156	166	10 Pumping level below land surfaces: 180 ft. after 512 hrs. pumping 1440 p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 1600 g.p.m.
		M GRAVEL SANDY CLAY		166	184	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —
		FINE SAND, SANDSTONE		184	194	12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
		FINE SAND, M GRAVEL		194	218	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
		SHALE		218	222	14 Nearest source of possible contamination: ft. 1200 Direction E Type POLL Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
		BROCK 218'				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Pallen Model number 814 HP 75 Volts 440 Length of drop pipe 210 ft. capacity 1200 m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation		(use a second sheet if needed)				
		3705 (TOPO)				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. L & H Drilling Co Inc 1166 Business name License No. Address Holden Kansas Signed Bill Chafford Date 9-2-75 Authorized representative				