

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

*DRB* *Spring Valley Ranch*

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County Wallace  Action SW 1/4 NW 1/4 SE 1/4 Section number 25 Township number T 14 Range number S R 41 *EM*

2. Distance and direction from nearest town or city: 5M S-5M W-1/2S of Sharon Springs, Ks  
Street address of well location if in city:  
3. Owner of well: Henry Bohl  
R.R. or street: Sharon Springs, Kansas 67758  
City, state, zip code:

4. Locate with "X" in section below: Sketch map:  
N  
W E  
S  
1 Mile

6. Bore hole dia. 8 in. Completion date 5/3/76  
Well depth 185 ft.

7.  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material PIST Height: Above or below  
Threaded  Welded GI Surface 15 in.  
RMP  PVC  Weight \_\_\_\_\_ lbs./ft.  
Dia. 5 in. to 185 ft. depth; Wall Thickness: inches or  
Dia. \_\_\_\_\_ in. to \_\_\_\_\_ ft. depth; gage No. 032

5. Type and color of material	From	To
Top Soil	0	10
Sand	10	70
Sand Rock	70	73
Sand	73	105
Sand Rock	105	108
Sand and Gravel	108	179
Oker and Shale	179	185
<i>BROCK 179</i>		
<i>3680</i> <i>179</i> <i>5501 BR</i>		
(Use a second sheet if needed)		

10. Screen: Manufacturer's name J and L

Type RMP Dia. 5"  
Slot/gauze 1/32" Length X 20"  
Set between X 165 ft. and X 185 ft.  
ft. and \_\_\_\_\_ ft.  
Gravel pack? YES Size range of material 1/8"

11. Static water level: \_\_\_\_\_ mo./day/yr.  
102 ft. below land surface Date 5/3/76

12. Pumping level below land surfaces:  
\_\_\_\_\_ ft. after NA hrs. pumping \_\_\_\_\_ g.p.m.  
\_\_\_\_\_ ft. after \_\_\_\_\_ hrs. pumping \_\_\_\_\_ g.p.m.  
Estimated maximum yield \_\_\_\_\_ g.p.m.

13. Water sample submitted: \_\_\_\_\_ mo./day/yr.  
Yes  No  Date \_\_\_\_\_

14. Well head completion:  
NO Pitless adapter \_\_\_\_\_ Inches above grade

15. Well grouted? YES  
With:  Neat cement  Bentonite  Concrete  
Depth: From 4 ft. to 18 ft.

16. Nearest source of possible contamination:  
ft. \_\_\_\_\_ Direction none Type \_\_\_\_\_  
Well disinfected upon completion? \_\_\_\_\_ Yes \_\_\_\_\_ No

17. Pump:  Not installed  
Manufacturer's name XXXXXXXXD  
Model number \_\_\_\_\_ HP \_\_\_\_\_ Volts \_\_\_\_\_  
Length of drop pipe \_\_\_\_\_ ft. capacity \_\_\_\_\_ g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

18. Elevation: 3680 *EM*  
Topography:  
 Hill  
 Slope  
 Upland  
 Valley

19. Remarks:  
This is a windmill well, we put up a mill over this well.

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Bartell Drilling 139  
Business name \_\_\_\_\_ License No. \_\_\_\_\_  
Address Wiana Kansas  
Signed Jane Bartell Date 7/25/76  
Authorized representative

T  
R  
E  
W  
25  
SUNNISE  
1/4 1/4 1/4