


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215
BBB

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Wallace	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 28	Township number T 14 S R 41	Range number 14W
2. Distance and direction from nearest town or city: X Sharon Springs 7 1/2 mi. West; 5 1/2 mi. Northe Street address of well location if in city:			3. Owner of well: Vaughn Young R.R. or street: City, state, zip code: Tribune, KS 67879		
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. <u>30</u> in. Completion date _____ Well depth <u>235</u> ft. <u>6-29-78</u>
Top Soil			0	52	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Large To Medium Gravel & Gravel			52	60	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Small Sandy Clay Streaks			60	64	9. Casing Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. <u>16</u> in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.188</u>
Large to Med. Gravel			64	73	10. Screens: Manufacturer's name <u>Cook - 225'-235'</u> Type <u>Wire Wrapp</u> Dia. <u>16"</u> Slot/gauze <u>10%</u> Length <u>60'</u> Set between <u>165</u> ft. and <u>225</u> ft. <u>Perf. W A Brown</u> <u>165-225</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>70% 1/2 X 5/8</u>
Sandy Clay			73	77	11. Static water level: _____ mo./day/yr. <u>110</u> ft. below land surface Date <u>7-8-78</u>
Large to Med. Gravel			77	94	12. Pumping level below land surfaces: <u>162</u> ft. after <u>2</u> hrs. pumping <u>1200</u> g.p.m. <u>185</u> ft. after <u>2</u> hrs. pumping <u>1900</u> g.p.m. Estimated maximum yield <u>2300</u> g.p.m.
Sandy Clay with Traces of Sandstone			94	125	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
Large Med. Gravel			125	133	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade
Sandy Clay & Small Med. Gravel			133	139	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Med. Gravel			139	151	16. Nearest source of possible contamination: ft. <u>5000</u> Direction <u>West</u> Type <u>Farmstead</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Sandy Clay & Sandstone			151	154	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Large Med. Gravel			154	165	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Western Well & Pump</u> <u>245</u> Business name License No. Address <u>P.O. Box 852 Colby, KS</u> Signed <u>Jerry Mollering</u> Date <u>7/24/78</u> Authorized representative
Sandy Clay - Sandstone			165	175	
Large Med. Gravel			175	196	
Sandy Clay			196	198	
Large Med. Gravel (Use a second sheet if needed)			198	205	
18. Elevation:		19. Remarks: BROCK ?			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

30% #1
T 14 S R 41 W
28
1/4 1/4 1/4 1/4