


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ellis	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 36	Township number T 15 S	Range number R 18 (W)
2. Distance and direction from nearest town or city: 2 1/2 - W of Schoenchen, Ks. Street address of well location if in city:			3. Owner of well: Harvey Werth R.R. or street: Rt 1 City, state, zip code: LaCrosse, Ks. 67548		
4. Locate with "X" in section below: <div style="text-align:center;">N 1 Mile W  E S 1 Mile</div>			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 30 in. Completion date 2-11-77 Well depth 37 ft.
Top soil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Brown & gray clay			3	13	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sand & gravel clean coarse loose			13	27	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 1 1/2 in. to 37 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7
Brown clay			27	29	10. Screen: Manufacturer's name Doerr Type steel Dia. _____ Slot 3/16 Length 13 Set between 25 ft. and 37 ft. ft. and _____ ft.
Sand & gravel clean coarse loose			29	37	Gravel pack? <input checked="" type="checkbox"/> Size range of material 3-4 1/2
Shale			37	45	11. Static water level: _____ mo./day/yr. 14 1/2 ft. below land surface Date 7-25-77
					12. Pumping level below land surfaces: 25 ft. after 1 hrs. pumping 425 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 200 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 7-25-77
					14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 1000 Direction West Type Barn/pond Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks 67530 Signature S. Kilgore Date 6-19-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 15 S R 18 W Sec 36 NW 1/4 NW 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5