


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County: Ellis		Fraction: se 1/4 nw 1/4 nw 1/4		Section number: 21		Township number: T 15 S R 19 E/W		Range number: 19	
2. Distance and direction from nearest town or city: 6-W 2-N of Schoenchen, Ks. Street address of well location if in city:				3. Owner of well: John Schmidt R.R. or street: box 24 City, state, zip code: Hays, Ks. 67601					
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 29 in. Completion date _____ Well depth 58 1/2 ft. 5-20-75		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material				From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
top soil				0		2		9. Casing: Material steel Height: Above or Below _____ Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 58 1/2 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7	
brown clay				2		10		10. Screen: Manufacturer's name _____ Johnson Type steel Dia. _____ Slot size 3/16 Length 14 Set between 4 1/2 ft. and 58 1/2 ft. _____ ft. and _____ ft.	
brown sand & gravel loose clean				10		21		Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8	
hard rock				21		22		11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 2-18-75	
sand & gravel clean coarse loose				22		50		12. Pumping level below land surfaces: 18 ft. after 1 hrs. pumping 70 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 600 g.p.m.	
sand & gravel coarse loose fine				50		58		13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 2-18-75	
black shale				58		58 1/2		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
								15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
								16. Nearest source of possible contamination: ft. 800 Direction se Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
								17. Pump: _____ Not installed Manufacturer's name Fairbanks Morse Model number 6-LOMA HP 50 Volts 460 Length of drop pipe 50 ft. capacity 500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)									
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 13 1/4 Business name License No. Address Great Bend, Ks. 67530 Signed S. Kilgore Date 6-19-74 Authorized representative			

T 15 S R 19 E NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5