USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Ellis		SE/NE/SE¼	22	15	19

Distance and direction from nearest town or city: 3W-1N-1W-¼N of /Schoenchen, Ks.
Street address of well location if in city:

3 Owner of well: Ed Hurl
Address: Schoenchen, KS.

Locate with "X" in section below: Sketch map:

N, W, E, S, X, 1 Mile

4 Well depth: 25 ft. Date of completion 2-21-75
Well diameter 9 in.

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐

7 Casing: Material pvc Height: above/below
Threaded ☐ Welded ☒ Surface 14 in.
Diam. Weight 160 lbs./ft.
5 in. to 15 ft. depth Drive shoe? ☐ Yes ☐ No
in. to ft. depth

2

Type and color of material	From	To
Sandy top soil	0	2
Sandy brown clay	2	5
Sand & gravel clean, coarse, loose	5	20
Sand Medium loose	20	27
Blue clay	27	30

(use a second sheet if needed)

8 Screen:
Manufacturer R & B
Type pvc Dia. 5
Slot/gauze 1/16 Length 10
Set between 15 ft. and 25 ft.
Fittings: 3/4-3/8-1/16
Gravel pack ☒ Yes ☐ No Size range of material Gm#3

9 Static water level:
11 ft. below land surface Date 2-21-75

10 Pumping level below land surfaces:
11 ft. after 1 hrs. pumping 20 g.p.m.
ft. after hrs. pumping g.p.m.
Estimated maximum yield 40 g.p.m.

11 Water sample submitted:
☒ Yes ☐ No Date 2-22-75

12 Well head completion:
☐ Pitless adapter ☒ Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ Neat cement ☐ Bentonite ☐
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination:
ft. 250 Direction NW Type feed yard
Well disinfected upon completion? ☒ Yes hth ☐ No

15 Pump: ☒ Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.m.p.
Type:
☐ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Certrifugal ☐ Other

16 Remarks: elevation

Topography:
☐ Hill
☐ Slope
☒ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Rosencrantz-Bemis License No. 134
Address Great Bend, Ks.
Signed Fredia Dodson Date 2-24-75
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

677-H