WATER WELL RECORD (WWC-5)

Constructed

KOLAR	DOC	Ю	164288	
-------	-----	---	--------	--

	KOLAR DOG	1642884	WELL ID
√	Original Record	\square Correction	☐ Change in Well Use

OC.	ACITA	WA	TED	WEL	

LOCATION	, which wer															
Latitude	38.698299	Longitude	-99.413885	Section	34	Township	15	Range	19	□E ✔W Fraction	SE	1/4	SE	1/4	SE	1/4
Datum	WGS84	Elevation	2028	County	Ellis											

WATER WELL OWNER

Name	Clinton	1	Werth				
Business							
	4503 Danby Lane						
Address	Hays	KS	67601				
Well location	Intersection of 200 Ave & A North 600' & west 400'						
at owner's address							

CONSTRUCTION	
Borehole interval:	Borehole diameter:
from 0 to 420 ft.	9 in.
fromtoft.	in.
Casing height above land su	
If casing height is less the has a variance been appr	an 12 in.
*variance not required for or environmental remed	diation wells
Casing type: Therr	
Blank casing interval:	
Blank casing diameter:	
Casing joints:	
Weight: lbs	
Wall thickness or gauge	no.: SDR17
Blank casing interval:	ft. toft.
Blank casing diameter:	in.
Casing joints:	
Weight: lbs	s/ft.
Wall thickness or gauge	
Grout interval: 5 ft. to	
Grout material: Ben	
Grout interval:ft. to	
Grout material:	

Screen / perforation material	: PVC
Screen / perforation opening	gs: Saw cut
Screen / perforation intervals	
From 360 ft. to 420	ft.
Slot size 32 unit	
From ft. to	ft.
Slot sizeunit	
Gravel pack intervals:	
Gravel pack not used: □	Gravel size in
From 0 ft. to	
Gravel pack not used:	
From 60 ft. to 42	<u>20</u> ft.

WELL WATER USE

WELL WATER USE	NEAREST SOURCE OF POTENTIAL CONTAMINATION
Domestic Household	Source: Livestock pens
COMPLETION	Distance from well: 900 Direction from well: S
Depth of completed well: 420 ft. Depth(s) groundwater encountered:	Source Feedlot description:
(1) ft.; (2) ft.;	Source:
(3) ft.; (4) _ dry well	Distance Direction
Static water level in well: 142 ft. ✓ measured below land surface on (mm/dd/yy): 04/22/2022	from well: from well: Source description:
measured above land surface on (mm/dd/yy):	☐ No potential source of contamination within 100 feet.
Estimated yield: 35 gpm	PERMIT & ID NUMBERS (AS REQUIRED)
Water level was:ft. afterhours pumpinggpm Pump installed? □ Yes ✔ No	DWR Application No.:KDHE / EPA Project Code:Site Name:
Tump motation: 🗆 165 V 110	KDHE UIC Class V Form Completed: ☐ Yes ☐ No
Water well disinfected? ✓ Yes □ No	County Permit: ☐ Yes ☐ No Permit ID:
Date disinfected (mm/dd/yy):04/22/2022	Lease Name & Well #:
Aquifer, if known:	# of boreholes: # of dewatering wells:
LITHOLOGIC LOG	

FROM	то	LITHOLOGY INTERVALS
Attache	Attache	Attached

COMMENTS

CONTRACTOR'S OR LANDOWNERS CERTIFICATION

Send one copy to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well. KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT

Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367 (785) 296-3565 | K.S.A. 82a-1212 | v2022c

Form	WWC5.2 - Water Well Record				
Doc ID	1642884				
Well Owner	Clinton Werth				
Contractor	Nash Water Well Service, LLC				

Lithology

Lithology		
From 1	To .	Ethology Intervals
0	3	,top soil
3	28	tan yellow clay with rock, streaks and layers
28	205	blue shal with rock streaks, and layers
205	215	,white gray clay
215	225	gray clay,
225	229	,tan clay
229	245	gray white clay with thin sandstone streaks
245	259	,brown clay
259	265	red clay
265	285	tan gray red clay
285	300	,brown gray clay
300	320	gray clay with thin sandstone, streaks
320	332	gray clay
332	350	blue gray clay/shale with thin sandstone streaks
350	352	red clay
352	360	gray sandstone with gray clay
360	380	,gray sandstone
380	400	gray clay with gray sandstone,
400	420	,blue shale
400	420	