

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction NE 1/4 SW 1/4 SW 1/4	Section number 4	Township number T 15 S	Range number R 2 W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 3 SE SALINA				3. Owner of well: Norman Yenkey R.R. or street: 2070 Roach City, state, zip code: Salina 76 67401		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 in. Completion date 7-14-76 Well depth 39 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				From	To	9. Casing: Material _____ Height: <u>Above</u> or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 39 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. Sched 40
Colluvium:						10. Screen: Manufacturer's name Sloop
Clay, lt brown				0	6	Type Sloop Dia. 4" Slot/gauze 1/16 Length 7' Set between 27 ft. and 31 ft. 36 ft. and 39 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/10"
Heavy fine						11. Static water level: _____ mo./day/yr. 4 ft. below land surface Date 7-14-76
Sandstone, medium, brown						12. Pumping level below land surfaces: 26 ft. after 1 hrs. pumping 6 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 7 g.p.m.
& yellow, contains some				6	38	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
interbedded shale 36-38						14. Well head completion: _____ <input type="checkbox"/> Pitless adapter 12 inches above grade
Wellington fine						15. Well grouted? <input checked="" type="checkbox"/> Y With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 13 ft.
Shale greenish-grey & gray				38	40	16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydraulic Drilling 126 Business name _____ License No. _____ Address Salina 76 Signed Ed Faust Date 9-1-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 15 S R 2 W E/W 4 NE SW SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5