

1. Location of well: County Saline		Fraction SW 1/4 NE 1/4 NE 1/4		Section number 5		Township number T 15 S R 2W E/W																															
2. Distance and direction from nearest town or city: 2 M. S + 2 M. E. Salina				3. Owner of well: Ron Dougherty R.R. or street: 2430 Drake Place City, state, zip code: Salina Kans 67401																																	
4. Locate with "X" in section below: <div style="display: flex; align-items: center; margin-top: 10px;"> <div style="text-align: center; margin-right: 10px;"> <p>1 Mile</p> <p>1 Mile</p> </div> <div> <p>Sketch map:</p> </div> </div>				6. Bore hole dia. 6 in. Completion date 10/23/78 X Well depth 33 ft.																																	
5. Type and color of material <table border="1" style="width:100%; border-collapse: collapse; margin-top: 10px;"> <thead> <tr> <th style="width:70%;"></th> <th style="width:15%;">From</th> <th style="width:15%;">To</th> </tr> </thead> <tbody> <tr> <td>Colluvium:</td> <td></td> <td></td> </tr> <tr> <td>Clay, sandy, buff</td> <td>0</td> <td>8</td> </tr> <tr> <td>Sand, fine to medium, silty</td> <td>8</td> <td>13</td> </tr> <tr> <td>Kinross fm:</td> <td></td> <td></td> </tr> <tr> <td>Sandstone, fine to medium, soft, yellow</td> <td>13</td> <td>19</td> </tr> <tr> <td>Sandstone, fine to medium, firm, brown</td> <td>19</td> <td>20</td> </tr> <tr> <td>Shale, dark gray</td> <td>20</td> <td>33</td> </tr> <tr> <td>Wellington fm:</td> <td></td> <td></td> </tr> <tr> <td>Shale, firm, gray-green</td> <td>33</td> <td>35</td> </tr> </tbody> </table>					From	To	Colluvium:			Clay, sandy, buff	0	8	Sand, fine to medium, silty	8	13	Kinross fm:			Sandstone, fine to medium, soft, yellow	13	19	Sandstone, fine to medium, firm, brown	19	20	Shale, dark gray	20	33	Wellington fm:			Shale, firm, gray-green	33	35	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
					From	To																															
				Colluvium:																																	
				Clay, sandy, buff	0	8																															
Sand, fine to medium, silty	8	13																																			
Kinross fm:																																					
Sandstone, fine to medium, soft, yellow	13	19																																			
Sandstone, fine to medium, firm, brown	19	20																																			
Shale, dark gray	20	33																																			
Wellington fm:																																					
Shale, firm, gray-green	33	35																																			
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				9. Casing: Material <input type="checkbox"/> Height: above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 4 in. to 21.5 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 300																																	
10. Screen: Manufacturer's name Skop Type slots Dia. 4" Slot/gauze 1/16" Length 3' Set between 18.5 ft. and 21.5 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/10"				11. Static water level: <input type="checkbox"/> mo./day/yr. 13 ft. below land surface Date 10/30/78																																	
12. Pumping level below land surfaces: 18 ft. after 2 hrs. pumping 3 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 3.5 g.p.m.				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____																																	
14. Well head completion: Pitless adapter 12 inches above grade				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.																																	
16. Nearest source of possible contamination: ft. 150 Direction W Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																	
18. Elevation:				19. Remarks:																																	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Nichols Drilling Co. 126 Business name Salina Kans License No. _____ Address _____ Signed Orl Faust Date 11/7/78 Authorized representative																																	