

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County SALINE Fraction 1/4 NW 1/4 NE 1/4 Section number 35 Township number T 15 S R 2 Range number 2 W

2. Distance and direction from nearest town or city: 5 mi. west of
Street address of well location if in city: DUPAUM RAN'S

3. Owner of well: SOUTHEAST OF SALINE
R.R. or street: NEW K-12 SCHOOL
City, state, zip code: MENTOR KANSAS 67465

4. Locate with "X" in section below: Sketch map: WELL

6. Bore hole dia. 15 in. Completion date 12-10
Well depth 69 ft.

7. ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

8. Use: ☐ Domestic ☒ Public supply ☐ Industry
☐ Irrigation ☐ Air conditioning ☐ Stock
☐ Lawn ☐ Oil field water ☐ Other

9. Casing: Material STEEL Height: Above or below
Threaded ☒ Welded ☐ Surface 24 in.
RMP ☐ PVC ☐ Weight 20 lbs./ft.
Dia. 6 in. to 69 ft. depth Wall Thickness: inches or
Dia. ☐ in. to ☐ ft. depth Gage No. 028

10. Screen: Manufacturer's name JOHNSON SCREEN
Type SS. WIRE Dia. 6"
Slot/gauze # 10 Length 12
Set between 57 ft. and 69 ft.
ft. and ☐ ft.
Gravel pack? ☒ Size range of material 1/8"

11. Static water level: ☐ ma./day/yr.
35 ft. below land surface Date 12-12-76

12. Pumping level below land surfaces:
47 ft. after 4 hrs. pumping 60 g.p.m.
☐ ft. after ☐ hrs. pumping ☐ g.p.m.
Estimated maximum yield 75 g.p.m.

13. Water sample submitted: ☐ ma./day/yr.
☐ Yes ☒ No Date ☐

14. Well head completion:
☒ Pitless adapter ☐ inches above grade

15. Well grouted? 42
With: ☐ Neat cement ☐ Bentonite ☒ Concrete
Depth: From 0 ft. to 20 ft.

16. Nearest source of possible contamination:
ft. 2000 Direction W Type WELL
Well disinfected upon completion? ☒ Yes ☐ No

17. Pump: ☒ Not installed
Manufacturer's name ☐
Model number ☐ HP ☐ Volts ☐
Length of drop pipe ☐ ft. capacity ☐ g.p.m.
Type:
☐ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Centrifugal ☐ Other

18. Elevation: ☐ Topography:
☒ Hill
☐ Slope
☐ Upland
☐ Valley

19. Remarks: Very Good Well

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report
is true to the best of my knowledge and belief.
Peterson Irrigation Inc 158A
Business name License No.
Address Box 150 Levensburg, KS
Signed Walter D. Peterson Date 1-3-77
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5