

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County SALINE Fraction NW 1/4 NE 1/4 Section number 35 Township number T 15 Range number S R 2

2. Distance and direction from nearest town or city: 5 miles West of
Street address of well location if in city: Gypsum, Kans

3. Owner of well: SOUTH EAST OF SALINE
R.R. or street: NEW K-12 SCHOOL
City, state, zip code: MENTOR KANSAS 67465

4. Locate with "X" in section below: Sketch map: WELL

WELL SITE # 1

5. Type and color of material

| | From | To |
|---------------------------------|-----------|-----------|
| <u>CLAY - SANDY</u> | <u>0</u> | <u>6</u> |
| <u>CLAY - RED - SANDSTONE</u> | <u>6</u> | <u>13</u> |
| <u>CLAY - YELLOWT "</u> | <u>13</u> | <u>26</u> |
| <u>CLAY - BLUE</u> | <u>26</u> | <u>28</u> |
| <u>SANDSTONE - RED</u> | <u>28</u> | <u>34</u> |
| <u>SANDSTONE - w/CLAY LAYER</u> | <u>34</u> | <u>42</u> |
| <u>SANDSTONE - SOFT</u> | <u>42</u> | <u>65</u> |
| <u>IRON PYRITE</u> | <u>65</u> | <u>67</u> |

6. Bore hole dia. 15 in. Completion date 12-8
Well depth 67 ft.

7. ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

8. Use: ☐ Domestic ☒ Public supply ☐ Industry
☐ Irrigation ☐ Air conditioning ☐ Stack
☐ Lawn ☐ Oil field water ☐ Other

9. Casing: Material STEEL Height: Above or below
Threaded ☒ Welded ☐ Surface 24" in.
RMP ☐ PVC ☐ Weight 20 lbs./ft.
Dia. 6 in. to 67 ft. depth Wall Thickness: inches or
Dia. 6 in. to 67 ft. depth gage No. 028

10. Screen: Manufacturer's name JOHNSON
Type S.S. #10 Dia. 6"
Slot/gauze WIDE MESH Length 12 ft
Set between 55 ft. and 67 ft.
ft. and 67 ft.
Gravel pack? yes Size range of material 1/8"

11. Static water level: 30 ft. below land surface Date 12-22-76 mo./day/yr.

12. Pumping level below land surfaces:
49 ft. after 4 hrs. pumping 60 g.p.m.
 ft. after hrs. pumping g.p.m.
Estimated maximum yield 75 g.p.m.

13. Water sample submitted: mo./day/yr.
Yes ☒ No ☐ Date

14. Well head completion:
☒ Pitless adapter 12 inches above grade

15. Well grouted? yes
With: ☐ Neat cement ☐ Bentonite ☒ Concrete
Depth: From 0 ft. to 20 ft.

16. Nearest source of possible contamination:
ft. 2000 Direction W Type WELL
Well disinfected upon completion? ☒ Yes ☐ No

17. Pump: ☒ Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
☐ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Centrifugal ☐ Other

18. Elevation:

19. Remarks: Very good well

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report
is true to the best of my knowledge and belief. IN W.
PETERSON FOUNDATION License No. 138A
Business name
Address Box 150 Lindsborg, KS
Signed William Peterson Date 1-3-77
Authorized representative

Topography:
☒ Hill
☐ Slope
☐ Upland
☐ Valley

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5