


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Eove</b>	Fraction <b>SW 1/4 SW 1/4 SW 1/4</b>	Section number <b>18</b>	Township number <b>T 15 S R 28 E W</b>	Range number <b>28</b>
2. Distance and direction from nearest town or city: <b>6E, 8 1/2 N, 1E of</b>				3. Owner of well: <b>Lamar Fullmer</b>		
Street address of well location if in city: <b>Healy, KS</b>				R.R. or street: <b>Shields, KS 67874</b>		
City, state, zip code:						
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>7-25-75</b>		
				Well depth <b>88</b> ft.		
5. Type and color of material		From		To		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Clay		0		7		8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sd coarse		7		20		9. Casing: Material <b>Steel</b> Height: <b>10</b> in. or below
Clay		20		25		Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>10</b> in.
Sd coarse		25		50		RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>31.67</b> lbs./ft.
Coarse sd clay		50		57		Dia <b>16</b> in. to <b>88</b> ft. depth Wall Thickness: inches or
Clay		57		71		Dia. <b>16</b> in. to <b>88</b> ft. depth Gauge No. <b>188</b>
Sd coarse		71		81		10. Screen: Manufacturer's name <b>Johnson</b>
Clay		81		84		Type <b>Galv Steel</b> Dia. <b>16</b> in.
Shale		84				Coarse gauge <b>100</b> Length <b>40</b> ft.
BROCK 84						Set between <b>48</b> ft. and <b>88</b> ft.
						ft. and <b>88</b> ft.
						Gravel pack? <b>yes</b> Size range of material <b>3/4-1/2</b>
						11. Static water level: <b>10</b> ft. below land surface Date <b>7-18-75</b>
						12. Pumping level below land surfaces:
						<b>38</b> ft. after <b>4</b> hrs. pumping <b>610</b> g.p.m.
						<b>46</b> ft. after <b>4</b> hrs. pumping <b>730</b> g.p.m.
						Estimated maximum yield <b>730</b> g.p.m.
						13. Water sample submitted: <b>Yes</b> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <b>7-18-75</b>
						Well head completion: <b>12</b> inches above grade
						<input checked="" type="checkbox"/> Well grouted? <b>12</b> inches above grade
						With: <b>Neat cement</b> <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete
						Depth: From <b>0</b> ft. to <b>10</b> ft.
						16. Nearest source of possible contamination: <b>2640</b> ft. Direction <b>SW</b> Type <b>Septic</b>
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <b>Not installed</b>
						Manufacturer's name <b>Peerless</b>
						Model number <b>80</b> HP <b>730</b> Volts <b>232</b>
						Length of drop pipe <b>80</b> ft. capacity <b>730</b> g.p.m.
						Type: <b>Submersible</b> <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <b>Hill</b> <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley <input type="checkbox"/>				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
				<b>Weishaar Drilling</b> <b>232</b>		
				Business name <b>Scott City, KS 67871</b> License No. <b>232</b>		
				Address <b>Scott City, KS 67871</b>		
				Signed <b>Scott City, KS 67871</b> Date <b>7-20-76</b>		
				Authorized representative <b>7-20-76</b>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5