

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CBB

1. Location of well:	County Cove	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 13	Township number T 15 S	Range number R 29 W
2. Distance and direction from nearest town or city: 10 1/2 miles north of Healy, Kansas Street address of well location if in city:			3. Owner of well: York Bros. R.R. or street: Box 218 City, state, zip code: Healy, Kansas 67850		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>72</u> ft. <u>5/10/79</u>	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
sandy clay		0	7	Casing: Material <u>Cement-Asbestos</u> Height: Above or below _____ <u>Galv Bandlock Coupler</u> Surface <u>60</u> in. Threaded _____ Welded _____ RMP _____ PVC _____ Weight <u>34</u> lbs./ft. Dia. <u>46</u> in. to <u>39</u> ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth Gage No. <u>7/8"</u>	
sand and gravel		7	72	10. Screen: Manufacturer's name _____ <u>Johnson Well Casing Co.</u> Type <u>Cement Asbestos</u> <u>16" I.D.</u> Slot/gauze <u>3/16"</u> Length <u>33 1/2</u> Set between _____ ft. and _____ ft. _____ ft. and _____ ft.	
shale		72	75	Gravel pack? <u>yes</u> size range of material <u>3/4 x 1/4</u>	
ROCK 72'				11. Static water level: _____ mo./day/yr. <u>10</u> ft. below land surface Date <u>3/10/79</u>	
				12. Pumping level below land surfaces: <u>25</u> ft. after <u>4</u> hrs. pumping <u>1200</u> g.p.m. <u>33</u> ft. after <u>8</u> hrs. pumping <u>2400</u> g.p.m. Estimated maximum yield <u>2400</u> g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>60</u> Inches above grade	
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.	
				16. Nearest source of possible contamination: ft. <u>200</u> Direction <u>North</u> Type <u>river</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name <u>Simmons</u> Model number _____ HP _____ Volts _____ Length of drop pipe <u>60</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling & Supply 232 Business name _____ Kansas No. _____ Address <u>Scott City, Kansas 67871</u> Signed <u>[Signature]</u> Date <u>6/7/79</u> Authorized representative	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 15 R 29 S 13 NW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5