

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CBC

1. Location of well:	County Gove	Fraction S/W/4 N/W/4 S/W/4	Section number 13	Township number T 15 S R 29	Range number #W
2. Distance and direction from nearest town or city: 6 E., 9 N. of Healy, Kansas Street address of well location if in city:			3. Owner of well: Lamar Fullmer R.R. or street: Shields, Kansas 67874 City, state, zip code:		
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>Sketch map:</p> </div> </div>			6. Bore hole dia. 26 in. Completion date Well depth 85 ft. 8-15-1978		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Cement Asbestos Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Band Surface 48 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft. Dia. 16 in. to 39 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 3/4"		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Johnson stainless steel & Type Cement Asbestos Dia. 16" Slot/gauze .125 & .100 Length 46' Set between 39 ft. and 65 ft. 65 ft. and 85 ft. Gravel pack? yes Size range of material 3/4 dn
					11. Static water level: _____ mo./day/yr. 9 ft. below land surface Date 7-2-78
					12. Pumping level below land surfaces: 51 ft. after 2 hrs. pumping 1350 g.p.m. 58 ft. after 2 hrs. pumping 1600 g.p.m. Estimated maximum yield 1600 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter 48 Inches above grade
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 5000 Direction West Type Farmstead Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name Layne & Bowler Model number _____ HP _____ Volts _____ Length of drop pipe 80 ft. capacity 1800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling & Sup. 232 Business name License No. _____ Address Scott City, KS 67871 Signature _____ Date 9/12/78 Authorized representative		

15-290
13
SUMMERS

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5