

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: <u>Saline</u>		County: <u>NE 1/4 SE 1/4 SW 1/4</u>		Section number: <u>1</u>		Township number: <u>T 15 S R 3</u>		Range number: <u>3</u>						
2. Distance and direction from nearest town or city: <u>M. S. Salina</u>					3. Owner of well: <u>General Battery Corp</u>									
Street address of well location if in city: <u></u>					R.R. or street: <u>South Industrial Area</u>									
					City, state, zip code: <u>Salina Kans 67401</u>									
4. Locate with "X" in section below:					Sketch map:									
<div style="text-align: center;"> </div>														
5. Type and color of material					From	To	6. Bore hole dia. <u>9</u> in. Completion date <u>4-20-76</u>							
<u>Clay, gray & buff</u>					<u>0</u>	<u>18</u>	Well depth <u>74</u> ft.							
<u>Sand, fine, silty</u>					<u>18</u>	<u>22</u>	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug							
<u>Sand, coarse & silty, lt gray</u>					<u>22</u>	<u>35</u>	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary							
<u>Gravel, fine to medium & sand (arkesian)</u>					<u>35</u>	<u>51</u>	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry							
<u>Clay, tan, interbedded with gravel</u>							<input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock							
<u>Coarse to fine sand (K-derived)</u>					<u>51</u>	<u>74</u>	<input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other							
<u>Wellington shale</u>							9. Casing: Material <u>PVC</u> Height <u>Above</u> of below							
<u>Shale, soft, dark gray</u>					<u>74</u>	<u>77</u>	Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in.							
							RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.							
							Dia. <u>1 1/2</u> in. to <u>7 1/2</u> ft. depth <u>74</u> ft. Wall Thickness: inches or							
							Dia. <u>1 1/2</u> in. to <u>7 1/2</u> ft. depth <u>74</u> ft. gage No. <u>028</u>							
							10. Screen: Manufacturer's name <u>Shop</u>							
							<u>3/32" 41-51</u>							
							Type <u>slots</u> Dia. <u>6</u>							
							Slot/gauze <u>1/16"</u> Length <u>20</u>							
							Set between <u>68</u> ft. and <u>74</u> ft.							
							<u>54</u> ft. and <u>58</u> ft.							
							Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>2.5mm</u>							
							11. Static water level: <u>20.5</u> ft. below land surface Date <u>3-20-76</u>							
							mo./day/yr. <u></u>							
							12. Pumping level below land surfaces:							
							<u>20.5</u> ft. after <u></u> hrs. pumping <u></u> g.p.m.							
							<u></u> ft. after <u></u> hrs. pumping <u></u> g.p.m.							
							Estimated maximum yield <u>150</u> g.p.m.							
							13. Water sample submitted: <u></u> ma./day/yr.							
							Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u></u>							
							14. Well head completion:							
							<u>Pitless adapter</u> <u>12</u> inches above grade							
							15. Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
							With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete							
							Depth: From <u>0</u> ft. to <u>10</u> ft.							
							16. Nearest source of possible contamination:							
							ft. <u></u> Direction <u></u> Type <u></u>							
							Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
							17. Pump:							
							<input type="checkbox"/> Not installed							
							Manufacturer's name <u>Meyers</u>							
							Model number <u></u> HP <u>20</u> Volts <u>240</u>							
							Length of drop pipe <u>60</u> ft. capacity <u>150</u> g.p.m.							
							Type:							
							<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine							
							<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating							
							<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other							
18. Elevation:					20. Water well contractor's certification:									
19. Remarks:					This well was drilled under my jurisdiction and this report is to the best of my knowledge and belief.									
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					Signature: <u>Ed Felt</u> License No. <u>5-17-76</u> Date: <u>5-17-76</u> Authorized representative									
										Well #2 for lawn irrigation				
										(Use a second sheet if needed)				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5