


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction NE 1/4 SE 1/4 SW 1/4	Section number 1	Township number T 15 S	Range number R 3 W E 1/4
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 mile S. Salina				3. Owner of well: General Battery Corporation R.R. or street: South Industrial Area City, state, zip code: Salina Kans 67401		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date Dec. 12 1975 Well depth 72.5 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Alluvial Terrace						9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.
Clay + silt, tan + buff		0		25		10. Screen: Manufacturer's name Skop Type PVC Dia. 6" Slot/gauze 1/16" Length 15' Set between 50 ft. and 59 ft. 466-72 ft. and 59 ft.
Sand, fine, silty, dark gray		25		36		11. Static water level: 18.5 ft. below land surface Date 12-12-75 mo./day/yr.
Gravel, fine to medium + sand		36		43		12. Pumping level below land surfaces: 40 ft. after 2 hrs. pumping 120 g.p.m. ft. after 2 hrs. pumping 150 g.p.m. Estimated maximum yield 150 g.p.m.
Clay, dark gray		43		47		13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 12-12-75 mo./day/yr.
Gravel, fine to coarse + sand (Arkosic)		47		58		14. Well head completion: <input type="checkbox"/> Pitless adapter 10 inches above grade
Gravel, coarse to medium + sand, (K-derived)		58		72		15. Well grouted? Y With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 13 ft.
interbedded with some clay, tan						16. Nearest source of possible contamination: Battery plant ft. 650 Direction NW Type plant Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Wellington fm:						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Shale, firm, blue-gray		72		75		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydramatic Drilling Co. 126 Business name _____ License No. _____ Address R.R. 2 Salina Ka Signed D. J. Fort Date 12-20-75 Authorized representative
18. Elevation: 1250 ±		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5