

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Saline</u>	Fraction <u>SW 1/4 NE 1/4 SW 1/4</u>	Section number <u>6</u>	Township number <u>T 15 S</u>	Range number <u>R 3 E</u>
2. Distance and direction from nearest town or city: <u>3 N - 1/2 W - 1/4 N.</u>		3. Owner of well: <u>Harold Larson</u>				
Street address of well location if in city: <u>Amolan Hous.</u>		R.R. or street: <u>799 Cnd. RR3 Box 904</u>				
		City, state, zip code: <u>Saline, Kan.</u>				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8"</u> in. Completion date <u>9-11-76</u>		
				Well depth <u>74</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug		
				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>PLTS</u> Height <u>Above</u> or below		
				Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18"</u> in.		
				RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>18</u> lbs./ft.		
				Dia. <u>5"</u> in. to <u>24</u> ft. depth		
				Wall Thickness: inches or		
				Dia. <u>5"</u> in. to <u>24</u> ft. depth		
				Gage No. <u>74"</u>		
5. Type and color of material		From To		10. Screen: Manufacturer's name <u>Winrock Inc.</u>		
<u>Top soil</u>		<u>0 3</u>		Type <u>P.V.C.</u> Dia. <u>5"</u>		
<u>gray clays</u>		<u>3 14</u>		Slot/gauze <u>1/16</u> Length <u>30</u> ft.		
<u>Red sandstone</u>		<u>14 16</u>		Set between <u>14</u> ft. and <u>30</u> ft.		
<u>Blue clays & sandstone layers</u>		<u>16 21</u>		<u>50</u> ft. and <u>74</u> ft.		
<u>Blue shaly clays & Iron pyrite</u>		<u>21 33</u>		Gravel pack? <u>yes</u> Size range of material <u>1/4-1/2"</u>		
<u>Blue shale</u>		<u>33 56</u>		11. Static water level: <u>11'</u> ft. below land surface Date <u>9-11-76</u>		
<u>Gray sandstone</u>		<u>56 56 1/2</u>		12. Pumping level below land surfaces:		
<u>Blue green shale & sandstone lenses</u>		<u>56 61</u>		<u>70</u> ft. after <u>2 1/2</u> hrs. pumping <u>8-1</u> g.p.m.		
<u>Blue shales</u>		<u>61 71</u>		<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.		
<u>Gray sandstone</u>		<u>71 75</u>		Estimated maximum yield <u>1-2</u> g.p.m.		
<u>dk Blue shale, fl.</u>		<u>75 90</u>		13. Water sample submitted: <u> </u> mo./day/yr.		
				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
				14. Well head completion:		
				<input checked="" type="checkbox"/> Pitless adapter <u>18</u> inches above grade		
				15. Well grouted? <u>yes</u>		
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From <u>4</u> ft. to <u>14</u> ft.		
				16. Nearest source of possible contamination:		
				ft. <u>1100</u> Direction <u>NE</u> Type <u>Septic</u>		
				Well disinfected upon completion? <u>yes</u> Yes <input type="checkbox"/> No <input type="checkbox"/>		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name <u> </u>		
				Model number <u> </u> HP <u> </u> Volts <u> </u>		
				Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<u>The Larson well install his pump & pour 4ft sq slab around well.</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
				<u>Petersen Bros Inc</u> 138		
				Business name <u>Lindborgers</u> License No. <u> </u>		
				Address <u>Wally Peterson</u> Date <u>9-14-76</u>		
				Signed <u>Wally Peterson</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5