

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: <u>Saline</u>	Fraction: <u>NW 1/4 NW 1/4 SW 1/4</u>	Section number: <u>6</u>	Township number: <u>T 15 S</u>	Range number: <u>R 3 E</u>
2. Distance and direction from nearest town or city: <u>2 N - 1 W - 1/2 N</u>		3. Owner of well: <u>Harold Langan</u> Ph 913-827-8223				
Street address of well location if in city: <u>Smolan Kan.</u>		R.R. or street: <u>733 East RR 3 Box 904</u>				
		City, state, zip code: <u>Salina, Kans.</u>				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>8"</u> in. Completion date <u>7-2-76</u>	
					Well depth <u>68</u> ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug	
					<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
					<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock	
					<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <u>PLTS</u> Height: <u>Above</u> or below	
					Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in.	
					RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>18</u> lbs./ft.	
					Dia. <u>5</u> in. to <u>68</u> ft. depth Wall Thickness: inches or	
					Dia. <u>5</u> in. to <u>68</u> ft. depth gage No. <u>14</u>	
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>Just Screen</u>		
<u>Top soil</u>		<u>0</u>	<u>2</u>	Type <u>P.V.C.</u> Dia. <u>5"</u>		
<u>Gray sandy clays</u>		<u>2</u>	<u>13</u>	Slot/gauze <u>1/16</u> Length <u>22</u> ft.		
<u>Red sandstone</u>		<u>13</u>	<u>14</u>	Set between <u>13</u> ft. and <u>22</u> ft.		
<u>Gray clays</u>		<u>14</u>	<u>16</u>	<u>30</u> ft. and <u>68</u> ft.		
<u>Blue clays</u>		<u>16</u>	<u>20</u>	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8 - 1/4</u>		
<u>Sandstone & Iron pyrites</u>		<u>20</u>	<u>22</u>	11. Static water level: <u>2 1/2</u> ft. below land surface Date <u>9-2-76</u>		
<u>Gray clays</u>		<u>22</u>	<u>27</u>	12. Pumping level below land surfaces:		
<u>Water Bearing Red Sandstone</u>		<u>27</u>	<u>42</u>	<u>60</u> ft. after <u>3</u> hrs. pumping <u>4-6</u> g.p.m.		
<u>Blue shales</u>		<u>42</u>	<u>44</u>	<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.		
<u>Iron pyrites some Marcasite</u>		<u>44</u>	<u>46</u>	Estimated maximum yield <u>8</u> g.p.m.		
<u>Blue shales</u>		<u>46</u>	<u>57</u>	13. Water sample submitted: <u> </u> mo./day/yr.		
<u>Iron</u>		<u>57</u>	<u>6"</u>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>		
<u>Blue shales</u>		<u>57 1/2</u>	<u>75</u>	14. Well head completion:		
				<input checked="" type="checkbox"/> Pitless adapter <u>18</u> inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> <u> </u>		
				With: <u> </u> Neat cement <u> </u> Bentonite <u> </u> Concrete		
				Depth: From <u>3</u> ft. to <u>12</u> ft.		
				16. Nearest source of possible contamination:		
				ft. <u>140</u> Direction <u>N.E.</u> Type <u>Septic</u>		
				Well disinfected upon completion? <u> </u> Yes <u> </u> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name <u> </u>		
				Model number <u> </u> HP <u> </u> Volts <u> </u>		
				Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m.		
				Type:		
				<input checked="" type="checkbox"/> Submersible <u> </u> Turbine		
				<u> </u> Jet <u> </u> Reciprocating		
				<u> </u> Centrifugal <u> </u> Other		
18. Elevation:	19. Remarks:			20. Water well contractor's certification:		
Topography:	<u>Mr Langan Installed his own pump.</u> <u>+ pitless unit. He well pour concrete slab</u> <u>around well min. 4 sq ft.</u>			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Dutton Bros Inc</u> <u>138</u> Business name License No. Address <u>Lindsborg Kan</u> Signed <u>Wally Peterson</u> Date <u>9-14-76</u> Authorized representative		
<input checked="" type="checkbox"/> Hill						
<u> </u> Slope						
<u> </u> Upland						
<u> </u> Valley						

Forward the white, blue and pink copies to The Department of Health and Environment

Form WWC-5