


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 6	Township number T 15 S	Range number R 3 E
2. Distance and direction from nearest town or city: 2 miles north of Smolan, 3/4 west and 1/8 mile north		3. Owner of well: Clifford Clark		R.R. or street: 1550 South Broadway		
Street address of well location if in city: 1/8 mile north		City, state, zip code: Salina, Kansas 67401				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 5/6/77		
				Well depth 58 ft.		
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug		
Sand and clay		0	22	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Blue		22	54	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
Gray		54	58	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material plst Height: Above or below 18 in.		
				Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in.		
				RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 0.258 lbs./ft.		
				Dia. 5 in. to 58 ft. depth Wall thickness: inches or		
				Dia. 5 in. to 58 ft. depth gage No. 0.258		
				10. Screen: Manufacturer's name Western Plastics		
				Type RMP Dia. 5 1/2		
				Slot/gauze 3/32 Length 40		
				Set between 18 ft. and 48 ft.		
				Gravel pack? Yes Size range of material 1/16 to 3/8		
				11. Static water level: 16 ft. below land surface Date 5/6/77		
				12. Pumping level below land surfaces:		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				Estimated maximum yield 8 g.p.m.		
				13. Water sample submitted: ____ mo./day/yr.		
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
				14. Well head completion:		
				Pitless adapter 18 inches above grade		
				<input checked="" type="checkbox"/> Well grouted? Yes		
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From ____ ft. to ____ ft.		
				16. Nearest source of possible contamination:		
				ft. ____ Direction ____ Type none		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name ____		
				Model number ____ HP ____ Volts ____		
				Length of drop pipe ____ ft. capacity ____ g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography:	Pasture		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Rader Drilling Co. 194						
Business name Carlton, Kans. 67429						
<input checked="" type="checkbox"/> Hill			Address Carlton, Kans. 67429			
<input type="checkbox"/> Slope			Signed Walter Rader Date 5-23-77			
<input type="checkbox"/> Upland			Authorized representative			
<input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-3