


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BBI

1. Location of well:		County Logan	Fraction SE 1/4 NW 1/4 NW 1/4	Section number 2	Township number T 15 S R	Range number 35 E W
2. Distance and direction from nearest town or city: 9S, 1/2 W of Street address of well location if in city: Russell Springs, KS			3. Owner of well: Eve L. Wells R.R. or street: Box 233 City, state, zip code: Brewster, KS 67732			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 9 in. Completion date _____ Well depth 44 ft. 8-24-77			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Clay			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Sdy clay Soft			9. Casing: Material Plas. Height Above or below Threaded <input type="checkbox"/> Welded Glue surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.8 lbs./ft. Dia. 5 in. to 24 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .250			
Shale			10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5 in. Slo gauge 1/16 Length 20 ft. Set between 24 ft. and 44 ft. ft. and _____ ft. Gravel pack? yes Size range of material 1/4-1/8			
BROCK 37'			11. Static water level: _____ mo./day/yr. 24 ft. below land surface Date 8-22-77			
			12. Pumping level below land surfaces: 34 ft. after 1 hrs. pumping 4 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 4 g.p.m.			
			13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.			
			16. Nearest source of possible contamination: ft. 2640 Direction NW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: _____ Not installed Manufacturer's name Aermotor Model number _____ HP _____ Volts _____ Length of drop pipe 36 ft. capacity 4 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal Windmill <input checked="" type="checkbox"/> Other			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scotts Glen, KS 67871 Signed <i>[Signature]</i> Date 8-24-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5