

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

BCC

1. Location of well:	County Wallace	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 30	Township number T 15 S R 38	Range number E 10
2. Distance and direction from nearest town or city: 1 1/2 N, 3 1/2 W, 1 1/2 N			3. Owner of well: Paul Larson		
Street address of well location if in city: of Selkirk, KS			R.R. or street: City, state, zip code: Sharon Springs, KS 67758		
4. Locate with "X" in section below:			Sketch map:		
			<p>6. Bore hole dia. 26 in. Completion date _____ Well depth: 220 ft. 5-19-76</p> <p>7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.67 lbs./ft. Dia. 16 in. to 220 ft. depth; Wall Thickness _____ inches or Dia. _____ in. to _____ ft. depth; gage No. .188</p> <p>10. Screen: Manufacturer's name _____ Free Flow Type Prime Steel Dia. 16 in. Slot gauge .125 Length 50 ft. Set between 1 1/2 ft. and 220 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 3/4-4 ft.</p> <p>11. Static water level: _____ mo./day/yr. 140 ft. below land surface Date 4-28-76</p> <p>12. Pumping level below land surfaces: 175 ft. after 4 hrs. pumping 650 g.p.m. 191 ft. after 4 hrs. pumping 780 g.p.m. Estimated maximum yield 780 g.p.m.</p> <p>13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____</p> <p>14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade <input checked="" type="checkbox"/> Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <input checked="" type="checkbox"/> 0 ft. to <input checked="" type="checkbox"/> 15 ft.</p> <p>16. Nearest source of possible contamination: Septic ft. 500 Direction W Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Simmons Model number US HP 60 Volts 460 Length of drop pipe 200 ft. capacity 780 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p>		
5. Type and color of material					
		From	To		
Clay		0	29		
Gyp		29	56		
Sdy clay		56	77		
Fine sd clay		77	130		
Sd coarse		130	138		
Clay		138	146		
Sd coarse		146	156		
Sd rock H		156	158		
Clay		158	167		
Fine sd clay		167	177		
Sd coarse		177	190		
Fine sd		190	200		
Fine sd clay		200	205		
Sd coarse		205	220		
Clay yellow		220	225		
Shale (Use a second sheet if needed)		225			
18. Elevation:	19. Remarks: BROOK 220'		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signature [Signature] Date 7-21-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

15 380 30 1/4 1/4 1/4 1/4