

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BBC

1. Location of well:		County Wallace	Fraction SW 1/4 NW 1/4 NW 1/4	Section number 31	Township number T 15 S	Range number R 38 E
2. Distance and direction from nearest town or city: 1 1/2 N, 3 1/2 W, 1 N, 1/4 E			3. Owner of well: Floyd Larson			
Street address of well location if in city: 1/4 S of Selkirk, KS			R.R. or street: City, state, zip code: Sharon Springs, KS 67758			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>224</u> ft. <u>5-18-76</u>		
		<p>Septic</p> <p>1/4 mi.</p> <p>X well</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP _____ PVC _____ Weight <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>224</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>188</u>		
Clay		20	22	10. Screen: Manufacturer's name _____ Free Flow Type <u>Prime Steel</u> Dia. <u>16 in.</u> <input checked="" type="checkbox"/> Slotted gauze <u>125</u> Length <u>50 ft.</u> Set between <u>174</u> ft. and <u>224</u> ft.		
Gyp		22	51	Gravel pack? <input checked="" type="checkbox"/> Yes _____ ft. and _____ ft. Size range of material <u>3/4-1/2</u>		
Sdy clay		51	59	11. Static water level: _____ mo./day/yr. <u>138</u> ft. below land surface Date <u>4-22-76</u>		
Clay		59	83	12. Pumping level below land surfaces: <u>176</u> ft. after <u>8</u> hrs. pumping <u>1150</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>1150</u> g.p.m.		
Sd coarse		83	89	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
Sdy clay		89	130	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade <input checked="" type="checkbox"/> Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.		
Sdy clay Fine sd clay		130	150	16. Nearest source of possible contamination: ft. <u>1320</u> Direction <u>NW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
Sd coarse		150	159	17. Pump: _____ Not installed Manufacturer's name <u>Simmons</u> Model number <u>US</u> HP <u>75</u> Volts <u>460</u> Length of drop pipe <u>210</u> ft. capacity <u>1150</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd rock		159	165	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address <u>Scott City, KS 67871</u> Signed _____ Date _____ Authorized representative _____ 27-21-76		
Sd coarse		165	169			
Rock H		169	172	18. Elevation: _____ 19. Remarks: <u>Clay</u> <u>Sd coarse</u> <u>Yellow</u> <u>BRUCK 221</u>		
Sd coarse		172	179			
Clay		179	181	Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
Sd coarse		181	190			
Sd rock H		190	191	19. Remarks: <u>BRUCK 221</u>		
Sd coarse (Use a second sheet if needed)		191	197			
18. Elevation: _____		197	203	22. _____		
19. Remarks: _____		203	221			
Topography: _____		221	225	22. _____		
_____ Hill		225	225			
_____ Slope		22. _____				
<input checked="" type="checkbox"/> Upland						
_____ Valley		22. _____				

T 15 S 38 E
 R 38 E
 Sec 31
 1/4 1/4 1/4 1/4