

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

DOC

1. Location of well:		County Wallace	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 21	Township number T 15 S R	Range number 39 E
2. Distance and direction from nearest town or city: 12N, 3 1/2W, 2N, 3 1/2W			3. Owner of well; Isaac Unruh			
Street address of well location if in city: of Selkirk, Kansas			R.R. or street: RFD #3-Box 82			
			City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date _____ Well depth <u>220</u> ft. <u>1-3-77</u>		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Plas.</u> Height <u>Above</u> or below Threaded _____ Welded <u>Glue</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC _____ Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>200</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250</u>		
Clay		0	19	10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5 in.</u> Gauge <u>1/16</u> Length <u>20 ft.</u> Set between <u>200</u> ft. and <u>220</u> ft. ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8</u>		
Rock Hard		19	25	11. Static water level: _____ mo./day/yr. <u>126</u> ft. below land surface Date <u>12-29-76</u>		
Sd coarse		25	70	12. Pumping level below land surfaces: <u>136</u> ft. after <u>1</u> hrs. pumping <u>10</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>10</u> g.p.m.		
Fine sd clay		70	80	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Sd coarse		80	92	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
Sdy clay		92	100	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From <u>0</u> ft. to <u>15</u> ft.		
Clay		100	110	16. Nearest source of possible contamination: ft. <u>2640</u> Direction <u>West</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
Sd rock		110	113	17. Pump: Not installed Manufacturer's name <u>Red Jacket</u> Model number <u>100A1</u> HP <u>1</u> Volts <u>220</u> Length of drop pipe <u>210</u> ft. capacity <u>10</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ <input type="checkbox"/> Jet _____ Reciprocating _____ <input type="checkbox"/> Centrifugal _____ Other _____		
Sd coarse		113	157	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name License No. Address <u>Scott City, KS 67871</u> Signed <u>[Signature]</u> Date <u>1-11-77</u> Authorized representative <u>1-11-77</u>		
Fine sd clay		157	175			
Sd med		175	181			
Sd coarse		189	218			
Yellow		218	220	BROCK 718'		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:				
Topography: ____ Hill ____ Slope <input checked="" type="checkbox"/> Upland ____ Valley						

T 15
 R 39
 S E
 Sec 21
 SW SW SE
 1/4 1/4 1/4