

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DC4

1. Location of well:		County Wallace	Fraction NE 1/4 SW 1/4 SE 1/4	Section number 22	Township number T 15 S R 39 E 10	Range number 39
2. Distance and direction from nearest town or city: 15N, 3 1/2W, 2N, Street address of well location if in city: 2 1/4W, 1/4N of Selkirk, KS			3. Owner of well: J. H. Coolidge R.R. or street: 10414 Camelot Circle City, state, zip code: Sun City, Arizona 85351			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>233</u> ft. <u>12-23-75</u>		
		<p>Septic ← 1/2 mi. X well</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Steel</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>233</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. <u>188</u>		
Clay		0	29	10. Screen: Manufacturer's name Free Flow		
Gyp H		29	54	Type <u>Prime Steel</u> Dia. <u>16 in.</u> Gauge <u>125</u> Length <u>40 ft.</u> Set between <u>193</u> ft. and <u>233</u> ft.		
Clay		54	67	Gravel pack? <u>yes</u> Size range of material <u>3/4-1</u> in.		
Sdy clay T		67	89	11. Static water level: _____ mo./day/yr. <u>192</u> ft. below land surface Date <u>10-11-75</u>		
Sd coarse		89	109	12. Pumping level below land surfaces: <u>192</u> ft. after <u>4</u> hrs. pumping <u>970</u> g.p.m. <u>200</u> ft. after <u>4</u> hrs. pumping <u>1100</u> g.p.m. Estimated maximum yield <u>1100</u> g.p.m.		
Clay		109	123	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Sdy clay T		123	130	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade <input checked="" type="checkbox"/> Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>10</u> ft. to <u>15</u> ft.		
Sd coarse		130	140	16. Nearest source of possible contamination: ft. <u>2920</u> Direction <u>W</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd rock H		140	148	17. Pump: Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>US</u> HP <u>75</u> Volts <u>460</u> Length of drop pipe <u>220</u> ft. capacity <u>1100</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay		148	157	18. Elevation: _____		
Sdy clay T		157	160	19. Remarks: Shale		
Sd coarse		160	166	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address <u>Scott City, KS 67871</u> Signature <u>[Signature]</u> Date <u>12-20-76</u> Authorized representative		
Clay sdy		166	186	Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
Fine sd clay		186	190	19. Remarks: BRUCK 228'		
Sd coarse		190	228	20. Water well contractor's certification: (Continued)		
Yellow (Use a second sheet if needed)		228	232	20. Water well contractor's certification: (Continued)		
18. Elevation: _____		232	235	20. Water well contractor's certification: (Continued)		

T 15 S R 39 E 10 Sec 22 NE 1/4 SE 1/4