


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

BBA

1. Location of well:	County Wallace	Fraction NE 1/4 NW 1/4 NW 1/4	Section number 11	Township number T 15	Range number S R 41 EW
2. Distance and direction from nearest town or city: Street address of well location if in city:		8 mi. S., 5 3/4 W of Sharon Springs, Kans.		3. Owner of well: Dewight Blaesi R.R. or street: City, state, zip code: Sharon Springs, Ks. 67758	
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 28 in. Completion date 5-29-76 Well depth 290 ft.
Top soil & clay			0	15	7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary
Clay & little lime			15	155	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other
Sand			155	183	9. Casing: Material steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP ___ PVC Weight 40 lbs./ft. Dia. 16 in. to 250 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 219
Clay (white & gummy)			183	190	10. Screen: Manufacturer's name W. A. Brown Type Free flo Dia. 16 <input checked="" type="checkbox"/> Gauze Perf. 2" Length 40 ft. Set between 250 ft. and 290 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material # -5/8
Sand & white clay streaked			190	195	11. Static water level: 160 ft. below land surface Date 4-28-76 mo./day/yr.
Sand			195	224	12. Pumping level below land surfaces: 210 ft. after 4 hrs. pumping 1500 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 2000 g.p.m.
Cemented Sand			224	225	13. Water sample submitted: ___ Yes <input checked="" type="checkbox"/> No Date
Sand			225	233	14. Well head completion: ___ Pitless adapter 12 inches above grade
Clay			233	244	15. Well grouted? <input checked="" type="checkbox"/> yes With: ___ Neat cement <input checked="" type="checkbox"/> Bentonite ___ Concrete Depth: From 0 ft. to 10 ft.
Sand			244	258	16. Nearest source of possible contamination: ft. ___ Direction ___ Type None Well disinfected upon completion? ___ Yes <input checked="" type="checkbox"/> No
Clay & Lime streaked			258	269	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ___ Model number ___ HP ___ Volts ___ Length of drop pipe ___ ft. capacity ___ g.p.m. Type: ___ Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other
Clay (yellow)			273	285	
Shale			285	290	
BROCK 273'					
(Use a second sheet if needed)					
18. Elevation:		19. Remarks: Level		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. ARK VALLEY PUMP & SUPPLY 123 Business name License No. Address Box 235 Holly, Colo. Signed Dave Smith Date 6-30 Authorized representative	
Topography: ___ Hill ___ Slope ___ Upland ___ Valley					

T 15 R 41 E
S 41 E
1/4 1/4 1/4