

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

1 - Copy to BWS
1 - Copy for pink

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Rush		Fraction NW 1/4 NW 1/4 NW 1/4		Section number 21		Township number T 16 S		Range number R 18 W E/W	
2. Distance and direction from nearest town or city: Street address of well location if in city: Liebanthal, Ks.				3. Owner of well: City of Liebanthal, Ks. R.R. or street: City, state, zip code:					
4. Locate with "X" in section below: N NW NE SW SE S 1 Mile W E 1 Mile				Sketch map: <i>street</i> <i>city building</i> <i>well</i>		6. Bore hole dia. 12 in. Completion date 5-10-80 Well depth 157 ft.			
5. Type and color of material				From		To		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
topsoil				0		4		8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
clay				4		21		9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 5.47 lbs./ft. Dia. 12 in. to 157 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .332	
sand and clay				21		34		10. Screen: Manufacturer's name JET STREAM Type PVC Dia. 12 Slot .031v Length 30ft. Set between 25 ft. and 35 ft. 136 ft. and 156 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/2	
blue shale				34		114		11. Static water level: <input type="checkbox"/> mo./day/yr. 80 ft. below land surface Date 5-10-80	
white dakota clay				114		138		12. Pumping level below land surfaces: 110 ft. after 5 hrs. pumping 35 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 35 g.p.m.	
sandstone				138		142		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
white dakota clay				142		144		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
sandstone				144		156		15. Well grouted? <input checked="" type="checkbox"/> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 22 ft.	
white dakota clay				156		157		16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(Use a second sheet if needed)								17. Pump: <input type="checkbox"/> Not installed Manufacturer's name FLINT & WALLING Model number 50FF11 HP 5 Volts 230 Length of drop pipe 126 ft. capacity 35 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Wells 199 Business name E. Hiway 40 Hays, Ks. Address Signature <i>[Signature]</i> Date 5-10-80 Authorized representative					

T 16 R 18 W Sec 21 NW 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5