

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

GREAT BEND
1:25900

1. Location of well:		County NESS	Tract NW 1/4 SW 1/4 NW 1/4	Section number 12	Township number T 16	Range number R 24	E/W
2. Distance and direction from nearest town or city: ABOUT 1 WEST & 4 NORTH. OF THIS IS APP. RANSOM.				3. Owner of well: KEITH BLACKSOME R.R. or street: City, state, zip code: RANSOM, KS. 67572			
4. Locate with "X" in section below: 		Sketch map: 		6. Bore hole dia. 9 in. Completion date 10/3/78 Well depth 33 ft.			
5. Type and color of material		From To		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
CLAY		0 10		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
SAND		10 30		9. Casing: Material PLAST Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 33 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250			
CLAY		30 33		10. Screen: Manufacturer's name CROWN LINE PLASTICS INC. Type PLASTIC Dia. 5" Slot/gauze 1/16 Length 10' Set between 23 ft. and 33 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-5/16"			
BROCK				11. Static water level: 24 ft. below land surface Date 10/3/78			
				12. Pumping level below land surfaces: NOT done _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____			
				14. Well head completion: NOT done _____ Pitless adapter _____ Inches above grade			
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
				16. Nearest source of possible contamination: ft. 500 Direction NW Type DRAW Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		19. Remarks: CONCRETE SLAB TO BE INSTALLED BY CUSTOMER. AT SURFACE OF GROUND.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D.E.L. DRILLING CO 303 Business name License No. Address 368 HILL CITY, KS. 67642 Signed Allen K. Jami Date 11/9/78 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5